




Recommendation: Fluid is in good condition overall. Ensure blanket gas is always maintained to prevent oxidation. Suggest submitting samples annually to proactively monitor fluid condition.

Comments: (GCD) 90% Distillation Point is abnormally high and there is a small increase in viscosity. Although neither are severe, these are symptoms of oxidation that has occurred.







Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.

Report ID: [02386372] (Generated: 11/24/2020 11:07:23) - Page 2 - Copyright 2020 Wearcheck Inc. All Rights Reserved.