

ROSEBURG PEMBROKE

Customer: PTRHTF30101

Roseburg Pembroke MDF Inc. 777 Fibreboard Drive Pembroke, ON K8A 6W5 Canada

Attn: Dan Havis Tel: (613)732-3939

E-Mail: danielh@rfpco.com

System Information

System Volume: 100000 gal Bulk Operating Temp: 518F / 270C

Heating Source:

Blanket:

Fluid: HEAT TRANSFER FLUID ISO 32

Make:


Sample Information


Lab No: 02387355 Analyst: Pierre Castagne Sample Date: 11/11/20 Received Date: 11/13/20 Completed: 11/24/20 Pierre Castagne

pierre.castagne@hollyfrontier.com


Recommendation: After reviewing the oil analysis result I contacted Robert Boal, Chief Stationary Engineer, Roseburg Forest Products Pembroke MDF, he informed me that they accidently transferred 500+ liters of coolant in the heat transfer tank. He also mentioned that prior to taking the sample they had transferred the oil into a metal tote to let it cool down. So essentially, the Iron, PQ rating could be related to the oil being in the tote. The high potassium that we are seeing is directly related to the accidental coolant in the heat transfer system. If possible, from a secure area (please do not transfer the oil in any container hasthis will bias the result), retake the sample and send it back for analysis

Comments: PQ levels are severe. Iron ppm levels are abnormal. Potassium ppm levels are severely high. Pentane Insolubles levels are severely high. Water contamination levels are marginally high. ppm Water contamination levels are marginally high.









Historical Comments	
11/04/20	Potassium ppm levels are severely high, investigate source of contamination. Water contamination levels are severely high, identify the source of water entry, eliminate the water. GCD Initial Boiling are low. Vent the system. Retake a sample in 1 months. Potassium ppm levels are severely high. Water contamination levels are severely high. ppm Water contamination levels are severely high.
11/03/20	GCD Initial Boiling are low. Potassium PPM level are abnormally high, investigate the presence of high potassium. Vent the system. Resample in 6 months. Potassium ppm levels are abnormally high.
11/02/20	The oil is good for continuous usage. Resample in 6 months.
09/05/19	Our GCD 90% are marginally high, we have slight oxydation of the oil. The oil is Ok for continuous use. (GCD) 90% Distillation Point is marginally low.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.