




[CIRCULATING PUMP DISCHARGE LINE] 5-02-76-12W6M H941 A/B


Customer: PTRHTF20204	System Information	Sample Information
ADVANTAGE OIL AND GAS 05-02-76-12W6M HYTHE, AB Canada Attn: Lorne Kingdon Tel: (780)552-3083 E-Mail: lkingdon@advantageog.com	System Volume: 110000 ltr Bulk Operating Temp: 410F / 210C Heating Source: Blanket: Fluid: PETRO CANADA PETRO-THERM Make: PETROTECH	Lab No: 02387524 Analyst: Clinton Buhler Sample Date: 11/02/20 Received Date: 11/16/20 Completed: 11/23/20 Clinton Buhler Clinton.Buhler@hollyfrontier.com

Recommendation: Sample results indicate that the fluid is suitable for continued service. Reduced flash point and fluid viscosity and increased low boiling vapor content suggest that there is some thermal degradation ongoing. It is advised to regularly vent off low boiling vapors from the expansion tank to help bring these parameters back in line. Please re-sample in 12 months, after thorough venting.

Comments: COC Flash Point is marginally low.




Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
11/02/20	11/16/20	2.0y	RETURNLINE TO BOILER	367 / 186	92.4	29.1	0.02	0.041	712 / 378	813 / 434	916 / 491	3.64
09/20/18	10/26/18	2.0y		468 / 242	88.8	34.9	0.043	0.048	727 / 386	817 / 436	920 / 493	0.00
Baseline Data				433 / 223		34.2	0.03		720 / 382	817 / 436	900 / 482	1.00





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
11/02/20	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
09/20/18	6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Baseline Data			0	0						0			0	0					0				0	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments

09/20/18	Sample results indicate that the heat transfer fluid is suitable for continued service. If total service time on fluid is 2 years, please re-sample in 12 months

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.