

[WENATCHEE PIT] HEAT TRANSFER SYSTEM

Customer: PTRHTF10239

Central Washington Asphalt 53847 Walla Walla River Rd Milton-Freewater, OR 97862 USA

Attn: Ron Jones Tel: (541)938-5205 E-Mail: ron@cwainc.us

System Information

System Volume: 220 gal

Bulk Operating Temp: Not Specified

Heating Source:

Blanket:

Fluid: VALVOLINE R&O HYDRAULIC OIL 46

Make:

Sample Information


Lab No: 02388209 Analyst: Ron LeBlanc Sample Date: 10/28/20 Received Date: 11/19/20 Completed: 12/07/20


Ron LeBlanc

Ronald.LeBlancSr@petrocanadalsp.com

Recommendation: Emulsified water in system. Viscosity is severely low for reported product. Flash point is extremely low. Suggest clean and flush system to gain proper operating levels.

Comments: Water contamination levels are severely high. Water contamination levels are severely high. ppm Water contamination levels are severely high. (GCD) % < 335°C is severely high. (GCD) 10% Distillation Point is severely low. COC Flash Point is severely low. Visc @ 40°C is severely low.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.