




[11-21-55-20W5M] H-802



| Customer: PTRHTF20228 | System Information | Sample Information |
|--|--|---|
| PEYTO EXPLORATION Box 7198 EDSON, AB T7E 1V4 Canada Attn: Logan Pillage Tel: (780)712-9444 E-Mail: Lpillage@Peyto.com | System Volume: 27000 ltr Bulk Operating Temp: 370F / 188C Heating Source: Blanket: Fluid: PETRO CANADA PETRO-THERM Make: ALCO | Lab No: 02392464 Analyst: Terry Veenstra Sample Date: 12/08/20 Received Date: 12/11/20 Completed: 12/16/20 Terry Veenstra terry.veenstra@petrocanadalsp.com |

Recommendation: TAN, Viscosity and Pentane insolubles are severely high indicating oxidation of the fluid . Ensure gas blanket is functioning. Considering filtering out solids.

Comments: Pentane Insolubles levels are severely high. Acid Number (AN) is severely high. Visc @ 40°C is severely high.




| Sample Date | Received Date | Fluid Age | Sample Location | Flash Point (COC) | Water (KF) | Viscosity (40°C) | Acid Number | Solids | GCD 10% | GCD 50% | GCD 90% | GCD % < 335°C |
|---------------|---------------|-----------|----------------------|-------------------|------------|------------------|-------------|--------|-----------|-----------|-----------|---------------|
| | mm/dd/yy | | | °F/°C | ppm | cSt | mg/KOH/g | %wt | °F/°C | °F/°C | °F/°C | % |
| 12/08/20 | 12/11/20 | 0y | discharge of pump | 453 / 234 | 18.9 | 60.0 | 0.64 | 1.33 | 744 / 396 | 839 / 448 | 899 / 482 | 0.69 |
| 04/07/20 | 04/14/20 | 0y | | 464 / 240 | 26.5 | 57.6 | 0.50 | 1.80 | 749 / 398 | 840 / 449 | 899 / 482 | 0.00 |
| 12/04/19 | 12/09/19 | 0y | DISCHARGE | 442 / 228 | 39.5 | 56.0 | 0.469 | 2.41 | 724 / 384 | 821 / 438 | 894 / 479 | 1.65 |
| 03/17/19 | 03/18/19 | 0y | DISCHARGE OF THE PUM | 448 / 231 | 28.8 | 57.4 | 0.03 | 1.35 | 735 / 391 | 832 / 445 | 895 / 479 | 0.73 |
| Baseline Data | | | | 433 / 223 | | 34.2 | 0.03 | | 720 / 382 | 817 / 436 | 900 / 482 | 1.00 |





| Sample Date | Iron | Chromium | Nickel | Aluminum | Copper | Lead | Tin | Cadmium | Silver | Vanadium | Silicon | Sodium | Potassium | Titanium | Molybdenum | Antimony | Manganese | Lithium | Boron | Magnesium | Calcium | Barium | Phosphorus | Zinc |
|---------------|------|----------|--------|----------|--------|------|-----|---------|--------|----------|---------|--------|-----------|----------|------------|----------|-----------|---------|-------|-----------|---------|--------|------------|------|
| 12/08/20 | 65 | 0 | 0 | 0 | 0 | 0 | 1 | 0 | 0 | 0 | 2 | 4 | 0 | 0 | 0 | 0 | 1 | 0 | 0 | 0 | 1 | 0 | 0 | 0 |
| 04/07/20 | 75 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2 | 4 | 0 | 0 | 0 | 0 | 1 | 0 | 0 | 0 | 1 | 0 | 0 | 0 |
| 12/04/19 | 78 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2 | 3 | 0 | 0 | 0 | 0 | 1 | 0 | 0 | 0 | 1 | 0 | 0 | 1 |
| 03/17/19 | 68 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2 | 4 | 0 | 0 | 0 | 0 | 1 | 0 | 0 | 0 | 1 | 0 | 0 | 0 |
| Baseline Data | | | 0 | 0 | | | | | | 0 | | | 0 | 0 | | | | 0 | | | | 0 | | |

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



| Historical Comments | |
|---------------------|---|
| 04/07/20 | The fluid is in a reasonable condition and suitable for further use. Viscosity and AN have remained at appr. the same level as the Dec. 2019 sample. Corrosion has not progressed further judging by AN and Fe content. Pentane Insolubles (solids) content is still too high (3x) but has decreased from 2.4% to 1.8%. Please re-sample in 6 months. (list Time on Oil) Pentane Insolubles levels are severely high. Visc @ 40°C is severely high. Acid Number (AN) is abnormally high. |
| 12/04/19 | The AN of the fluid has increased. AN has not reached the condemning limit yet (=1.0) but the acidity of the fluid is starting to cause more corrosion. Fe content increased from 68 to 78 ppm which is an indication of this. The viscosity of the fluid is high with 56 cSt/40C. This is the result of a high Pentane Insolubles (solids) content (2.41%). Filtration of the fluid is recommended. If filtration is in place, it is not efficient and should be looked at. Your Petro-Canada Tech Service Advisor can assist with this. Please re-sample in 6 months. |
| 03/17/19 | The viscosity and Pentane Insoluble (solids) content of the fluid are high. It is recommended to start filtration of the fluid and re-sample after filtration. Pentane Insolubles levels are severely high. Visc @ 40°C is severely high. |

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.