




[BONAVISTA ENERGY / LSD:5-29-55-19W5] HOT OIL BURNER


Customer: PTRHTF20039	System Information	Sample Information
BRENNTAG CANADA INC 3124-54TH AVENUE SE CALGARY, AB T2C 0A8 Canada Attn: Matthew Kryska Tel: E-Mail: mkryska@brenntag.ca	System Volume: 2000 ltr Bulk Operating Temp: 329F / 165C Heating Source: Blanket: Fluid: PETRO CANADA PETRO-THERM Make: PETRO-TECH	Lab No: 02393764 Analyst: Kevin McDermott Sample Date: 11/17/20 Received Date: 12/18/20 Completed: 12/21/20 Kevin McDermott kevin.mcdermott@hollyfrontier.com

Recommendation: Fluid condition is excellent. Please continue to submit samples annual to proactively monitor fluid condition.

Comments:




Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
11/17/20	12/18/20	9.0y	Hot oil filter	424 / 218	48.5	32.6	0.04	0.020	706 / 375	811 / 433	917 / 491	1.40
03/14/19	03/26/19	7.5y		406 / 208	231.6	32.3	0.022	0.020	688 / 364	800 / 427	908 / 487	3.17
09/27/18	10/04/18	7.0y		432 / 222	262.6	32.5	0.063	0.072	718 / 381	791 / 422	869 / 465	0.00
Baseline Data				433 / 223		34.2	0.03		720 / 382	817 / 436	900 / 482	1.00





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
11/17/20	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
03/14/19	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
09/27/18	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Baseline Data			0	0						0			0	0					0				0	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments	
03/14/19	The fluid is in good condition and suitable for further use. A combination of decreasing Flash Point, 10% GCD temperature and increasing low boiler vapor content indicates either minor thermal degradation of the fluid but more likely ingress of blanket gas if the blanket gas pressure is higher than 5 psig. In that case venting of low boiler vapors (light ends) to atmosphere is recommended to lower the 3.17%. Please re-sample in 6 months.
09/27/18	The fluid is in good condition and suitable for further use. The 90% GCD temperature is low. This is not an issue for fluid/system performance at this time and may be caused by nitrogen ingress if N2 blanket gas pressure is higher than 2-3 psig. Please vent off to atmosphere and re-sample in 12 months. (GCD) 90% Distillation Point is abnormally low.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.