

CALGARY, AB T2C 0A8 Canada
Attn: Matthew Kryska
Tel:
E-Mail: mkryska@brenntag.ca


System Volume: 23000 ltrLBulk Operating Temp: 417F / 214CAHeating Source:SBlanket:FFluid: PETRO CANADA PETRO-THERMCMake: ALCOA


Sample Information Lab No: 02393766 Analyst: Kevin McDermott Sample Date: 11/27/20 Received Date: 12/18/20 Completed: 12/22/20 Kevin McDermott kevin.mcdermott@petrocanadalsp.com

Recommendation: Fluid is in very good condition overall. The GCD 90% is a little higher than normal which is likely caused by some oxidation that has taken place - not severe. Continue to submit annual samples to proactively monitor fluid condition.


Comments:

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
11/27/20	12/18/20	14m	Heat medium return	446 / 230	31.6	35.9	0.18	0.302	729 / 387	819 / 437	929 / 499	0.44
11/21/19	12/03/19	30m	OUTSIDE SIGHT GLASS	453 / 234	<mark>375.9</mark>	35.2	0.026	0.139	698 / 370	792 / 422	908 / 487	1.49





Historical Comments



Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.