



WANSON TPC600 LNE

Customer: PTRHTF40135	System Information	Sample Information
VEGA INSIDERS B.V ENERGIE WEG UDENHOUT, Netherlands Attn: Wilbert Snijers Tel: E-Mail: w.snyers@klt.nl	System Volume: 1200 ltr Bulk Operating Temp: 536F / 280C Heating Source: Blanket: Fluid: PETRO CANADA PURITY FG HEAT TRANSFER FLUID Make: WANSON	Lab No: 02397738 Analyst: Matthias Voss Sample Date: 01/04/21 Received Date: 01/14/21 Completed: 02/02/21 Matthias Voss Matthias.Voss@petrocanadalsp.com

Recommendation: Fluid fit for further use. Send in next sample at regular service interval.

Comments: (GCD) 90% Distillation Point is abnormally high.

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
01/04/21	01/14/21	1m		460 / 238	8.8	35.8	0.85	0.149	739 / 393	827 / 442	926 / 497	0.30
Baseline Data				459 / 237		37.12	0.90		721 / 383	807 / 431	892 / 478	1.5



