

## **DRYER FT-600C**

## Customer: PTRHTF10242

ATHENS UTILITIES BOARD 220 ALFRED ST.

ATHENS, TN 37303 USA Attn: RUSSELL COLEMAN

Tel: (423)507-6067

E-Mail: rcoleman@aub.org

## System Information

System Volume: 264 gal

Bulk Operating Temp: 450F / 232C

Heating Source:

Blanket:

Fluid: PETRO CANADA CALFLO AF

Make: FENTON

## Sample Information

Lab No: 02398026 Analyst: Jake Finn Sample Date: 01/11/21 Received Date: 01/15/21 Completed: 01/27/21


Jake Finn

jake.finn@petrocanadalsp.com

Recommendation: Pentane Insolubles (solids) levels are severely high, indicating heavy contamination of solid oxidation byproducts in the oil. High acid number also points to fluid degradation. Drain and refill with new Calflo AF, replace filters and resample for new baseline.

Comments: Pentane Insolubles levels are severely high. Acid Number (AN) is abnormally high. (GCD) 90% Distillation Point is abnormally high. (GCD) 10% Distillation Point is marginally high. (GCD) 50% Distillation Point is marginally high.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.