

GFPT-FURTHER#1#2

Customer: PTRHTF60010

SYNLUBE INTERNATIONAL CO LTD 76/1 MOO.7 THACHIN

MUANG SAMUTSAKHON, 74000

THAILAND

Attn: CHERNPORN CHOBKUI

Tel: 034421290

E-Mail: chernporn@synlube.co.th

System Information

System Volume: 7000 ltr

Bulk Operating Temp: 554F / 290C

Heating Source:

Blanket:

Fluid: PETRO CANADA PURITY FG HEAT TRANSFER FLUID

Make: WANSON

Sample Information


Lab No: 02399577 Analyst: Philip Riley Sample Date: 01/11/21 Received Date: 01/25/21 Completed: 01/28/21


Philip Riley


philip.riley@petrocanadalsp.com


Recommendation: Flash Point very low and also viscosity is also low. If the system can be vented safely then recommend this is done. Low viscosity and flash are linked and likely a result of thermal cracking, producing light end molecules of lower flash pt. Upon cracking there will also be heavy molecules and sludges formed. If flash point cannot be recovered should look towards a fluid change


Comments: COC Flash Point is severely low. (GCD) 10% Distillation Point is abnormally low. Visc @ 40° C is abnormally low. (GCD) % < 335° C is marginally high.











Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]

0


Baseline Data

08/15/19

08/15/19

01/12/19

04/18/18



in 12 months to monitor the fluid conditions.

The fluid has adequate viscosity, flash point, distillation points. The acid number and solid content are all low. The oil is suitable for use, please take one sample

(GCD) % < 335°C is marginally high. COC Flash Point is abnormally low. (GCD) 10% Distillation Point is marginally low. Their is some evidence of thermal cracking which causes the light boiling molecules that reflect in the low flash point, and abnormal GCD. This is supported by the low viscosity also. System venting (if it can be done safely) is required as soon

as possible, otherwise the partial oil change is recommended. COC Flash Point is severely low. (GCD) 10% Distillation Point is abnormally low. (GCD) % < 335°C is marginally high. Viscosity trending towards low and COC Flash Pt very low. If the product can be safely vented to remove light molecules this should be done and a sample taken

The current fluid has normal viscosity and distillation point. The acid number, solid content and the contaminants are all low. The flash point is lower than the fresh

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.

afterwards to check if there is recovery of the flash point. If not then should consider an oil change COC Flash Point is severely low.

oil, but still acceptable. Please continue to run the oil and take one sample in 12 months to monitor the conditions.