




2 (F2)



Customer: PTRHTF30164	System Information	Sample Information
CENTRE TECHNO PNEU 100 RUE DES ATELIERS RIMOUSKI, QC G5M 1B4 CA Attn: Jean-Francois Marquis Tel: (418)724-4104 E-Mail: jfmarquis@technopneu.com	System Volume: 410 ltr Bulk Operating Temp: 350F / 177C Heating Source: Blanket: Fluid: PARATHERM NF Make:	Lab No: 02400096 Analyst: Yves Tremblay Sample Date: 01/21/21 Received Date: 01/27/21 Completed: 02/16/21 Yves Tremblay ytremblay154@gmail.com

Recommendation: Notre Indice d'Acidité (AN) est élevé. Il y a un léger craquage de l'huile Caloporteur.

Comments:




Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
01/21/21	01/27/21	5.0y		360 / 182	3.3	17.5	0.42	0.117	578 / 304	690 / 365	802 / 428	25.49
Baseline Data				342 / 172		17.9	0.04		572 / 300	689 / 365	808 / 431	22.7





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
01/21/21	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Baseline Data			0	0						0			0	0					0				0	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.