


## HEATTRANSFER


Customer: PTRHTF10226	System Information	Sample Information
LAKESIDE INDUSTRIES	System Volume: 0 gal	Lab No: 02402528
8198 Old Hwy 99 North Rd	Bulk Operating Temp: Not Specified	Analyst: Ron LeBlanc
Burlington, WA 98233 US	Heating Source:	Sample Date: 11/20/20
Attn: Rex Bebee	Blanket:	Received Date: 02/08/21
Tel:	Fluid: PETRO CANADA PETRO-THERM	Completed: 02/11/21
E-Mail:	Make:	Ron LeBlanc
rex.bebee@lakesideindustries.com		Ronald.LeBlancSr@HFSinclair.com

Recommendation: The (GCD) 90% Distillation Point is high indicating high boilers are above the new fluid levels. These can lead to deposits. Pentane insolubles and water level is high indicating contamination. Check strainer/filter for contamination. Resample in 3 months.

Comments: Pentane Insolubles levels are severely high. Acid Number (AN) is abnormally high. (GCD) 90% Distillation Point is marginally high.

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
11/20/20	02/08/21	0.0y		435 / 224	42.0	41.6	0.38	0.628	725 / 385	818 / 437	921 / 494	0.72
11/15/19	01/20/20	0.0y		442 / 228	22.8	40.6	0.479	0.658	727 / 386	796 / 424	887 / 475	2.36





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.