

RF04 GODET BOILER 2

Customer: PTRHTF10057

PROPEX RINGGOLD PLANT 428 ROLLINS INDUSTRIAL BLVD RINGGOLD, GA 30736 USA

Attn: MITCH HELTON Tel: (423)553-3723

E-Mail: MITCH.HELTON@PROPEXGLO

BAL.COM

System Volume: 0 gal

Bulk Operating Temp: 400F / 204C

System Information

Heating Source:

Blanket:

Fluid: PETRO CANADA CALFLO AF

Make:

Sample Information

Lab No: 02413407 Analyst: Jake Finn Sample Date: 03/17/21 Received Date: 04/06/21 Completed: 04/19/21


Jake Finn

jake.finn@hollyfrontier.com

Recommendation: This sample shows signs of copper and elevated 10% and 90% distillation points. The condition of the fluid is within specification however, and is suitable for continued use. Please resubmit for testing in one year.

Comments: Copper ppm levels are abnormal. (GCD) 90% Distillation Point is abnormally high. (GCD) 10% Distillation Point is marginally high.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.