

XST HOT OIL SYSTEM HEATING HTF

Customer: PTRHTF10048
MOMENTIVE PERFORMANCE MATERIAL
 703 SOUTH STREET
 NEW SMYRNA BEACH, FL 32168 USA
 Attn: Don Pultz
 Tel: (386)409-5524
 E-Mail: donald.pultz@momentive.com




System Information
 System Volume: 100 gal
 Bulk Operating Temp: 305F / 152C
 Heating Source:
 Blanket:
 Fluid: PETRO CANADA CALFLO AF
 Make: SPALTECH


Sample Information
 Lab No: 02416844
 Analyst: Jake Finn
 Sample Date: 04/15/21
 Received Date: 04/23/21
 Completed: 05/03/21
 Jake Finn
 jake.finn@hollyfrontier.com

Recommendation: 90% Distillation point (GCD) is marginally high, but sample otherwise indicates fluid is suitable for continued use. Please sample and resubmit for testing in one year.

Comments: (GCD) 90% Distillation Point is marginally high.




Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
04/15/21	04/23/21	3.0y	Sampling port	421 / 216	37.4	29.7	0.07	0.033	688 / 364	793 / 423	906 / 485	3.02
10/13/20	10/19/20	3.0y	SAMPLE PORT	428 / 220	82.4	29.6	0.06	0.087	684 / 362	791 / 422	895 / 479	3.51
05/05/20	05/11/20	2.0y	CAMPLING PORT	405 / 207	48.3	29.4	0.06	0.100	683 / 362	791 / 422	893 / 478	3.65
08/27/19	09/06/19	1.0y	PORT	439 / 226	145.4	29.2	0.064	0.130	676 / 358	790 / 421	894 / 479	4.53
05/23/19	05/24/19	1.0y	XST SAMPLE PORT	419 / 215	113.3	29.2	0.066	0.035	672 / 356	782 / 416	883 / 473	4.46
Baseline Data				435 / 224		32.7	0.03		693 / 367	790 / 421	887 / 475	2.5





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
04/15/21	4	0	0	0	0	1	0	0	0	0	3	0	0	0	0	0	0	0	0	0	0	0	265	2
10/13/20	4	0	0	0	0	2	0	0	0	0	3	0	0	0	0	0	0	0	0	0	0	0	270	2
05/05/20	4	0	0	0	0	1	0	0	0	0	2	0	0	0	0	0	0	0	0	0	0	0	276	2
08/27/19	4	0	0	0	0	1	0	0	0	0	3	0	0	0	0	0	0	0	0	0	0	0	276	2
05/23/19	4	0	0	0	0	2	0	0	0	0	3	0	0	0	0	0	0	0	0	0	0	0	263	2
Baseline Data			0	0						0			0	0					0				270	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments	
10/13/20	Fluid is satisfactory and suitable for continued use. Please re-submit sample in October 2021 Very light debris noticed in sample. Mitigation can be performed during a 'safe' down day. Change any system filters & filter system fluids with a kidney loop portable filter cart to maintain system cleanliness.
05/05/20	Petro-Canada CALFLO AF Fluid is suitable for continued use. Please re-submit next sample in May 2021
08/27/19	Sample is suitable for continued use. Please submit next sample on August 2020 Very light debris noticed in the fluid. During any shutdown periods, the fluid could be filtered thru a kidney loop system to eliminate any debris/contamination. Emulsified water noticed by the lab which should evaporate off during normal operation at these elevated operating temperatures.
05/23/19	Fluid is suitable for continued use. Please re-submit sample in May 2020 Fluid parameters appear to be in very satisfactory condition. Fluid appears to have a 'hazy' appearance and there is very lite debris present in the oil. Filtration of the fluid in the system during a safe 'down-time' could help in maintaining proper system cleanliness.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.