


H-1


Customer: PTRHTF20208	System Information	Sample Information
Plains Midstream Canada	System Volume: 1000 ml	Lab No: 02419199
PO Box 3210	Bulk Operating Temp: 500F / 260C	Analyst: Terry Veenstra
Range Road 221	Heating Source:	Sample Date: 04/28/21
Fort Saskatchewan, AB T8L 2T2 Canada	Blanket:	Received Date: 05/05/21
Attn: Marlon Gonzalez	Fluid: ESSO THERMOIL 32	Completed: 05/18/21
Tel: (780)992-2724	Make:	Terry Veenstra
E-Mail:		terry.veenstra@hollyfrontier.com

Recommendation: This oil viscosity is 5.1 cSt @ 40°C so is still the majority Essotherm Light (1156). The TAN is still quite low at 0.09 mgKOH/g and the flash point is still good @ 130°C indicating the fluid is in pretty good shape. The Pentane Insolubles are at 0.42% which is slightly higher than normal but still not critical. Consideration should be given to filtering this oil if it gets above 0.50%.

Comments: (GCD) 10% Distillation Point is severely low. (GCD) 90% Distillation Point is severely low. Visc @ 40°C is severely low. COC Flash Point is abnormally low.

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
04/28/21	05/05/21	30.0y	After Filtering syst	266 / 130	41.7	5.1	0.09	0.042	451 / 233	553 / 290	809 / 431	69.62
07/09/19	07/12/19	20.0y		255 / 124	77.1	5.4	0.140	0.028	445 / 229	558 / 292	818 / 437	66.87
12/04/18	12/20/18	0.0y		255 / 124	41.0	5.0	0.01	0.139	441 / 227	557 / 292	822 / 439	66.55





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.