



Customer: PTRHTF20249	System Information	Sample Information
Canfor - Plateau	System Volume: 190000 ltr	Lab No: 02422891
1399 Bearhead Rd.	Bulk Operating Temp: 455F / 235C	Analyst: Ray Rolston
Vanderhoof, BC V0J 3A2 Canada	Heating Source:	Sample Date: 05/12/21
Attn: Hans Pedersen	Blanket:	Received Date: 05/21/21
Tel: (250)567-8376	Fluid: PETRO CANADA PETRO-THERM	Completed: 05/28/21
E-Mail: Hans.Pedersen@canfor.com	Make: DELTECH	Ray Rolston
		Bay Bolston@hollyfrontier.com

Recommendation: Water content of sample was low at 20.7 ppm. Acid Number (AN) at 0.18 mg KOH/g is low which is good. COC Flash Point and GCD Distillation is good, although Initial Boiling Point (IBP) is a little low at 285 C indicating that some light fractions are present. Pentane Insolubles (solids) content is elevated at 0.564; the warning limit is 0.50%. Recommend investigating whether the heat transfer fluid can be filtered to remove this sediment. Re-sample in 6 months to monitor the fluid's condition.

Comments: Pentane Insolubles levels are severely high.

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
05/12/21	05/21/21	11.0y	Primary Pipe	442 / 228	20.7	35.3	0.18	0.564	710 / 377	797 / 425	915 / 491	1.11





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.

Report ID: [02422891] (Generated: 12/07/2021 14:48:26) - Page 2 - Copyright 2021 Wearcheck Inc. All Rights Reserved.