

[LSD / 6-25-45-10W5] H-704

Customer: PTRHTF20190
 Cenovus Sand Creek
 5023 54A Ave
 Eckville, AB T0M 0X0 Canada
 Attn: Brendon Emmett
 Tel: (780)898-7136
 E-Mail: brendon.emmett@cenovus.com




System Information
 System Volume: 43000 ltr
 Bulk Operating Temp: 455F / 235C
 Heating Source:
 Blanket:
 Fluid: PETRO CANADA PETRO-THERM
 Make: BORN


Sample Information
 Lab No: 02426841
 Analyst: Kevin McDermott
 Sample Date: 06/05/21
 Received Date: 06/14/21
 Completed: 06/16/21
 Kevin McDermott
 kevin.mcdermott@hollyfrontier.com

Recommendation: Fluid is in excellent condition.

Comments:




Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
06/05/21	06/14/21	4.0d	PUMP SAMPLE PUMP	421 / 216	29.1	32.0	0.01	0.030	719 / 382	818 / 437	911 / 488	2.47
04/14/21	04/23/21	25.0d	Pump discharge	417 / 214	182.5	37.6	0.07	0.042	710 / 377	831 / 444	929 / 499	5.89
01/31/20	02/04/20	23.0d	DISCHARGE P832	322 / 161	122.4	38.0	0.050	0.077	726 / 386	842 / 450	895 / 480	5.85
03/25/19	03/27/19	23.0d	OUTLET OF SURGE DRUM	324 / 162	126.4	37.3	0.048	0.013	739 / 393	841 / 450	913 / 489	3.14
03/01/19	03/07/19	22.0d	SUPPLY	306 / 152	31.3	38.3	0.053	0.080	690 / 366	825 / 441	900 / 482	6.86
Baseline Data				433 / 223		34.2	0.03		720 / 382	817 / 436	900 / 482	1.00





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
06/05/21	4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	4	0	4	3
04/14/21	16	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
01/31/20	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
03/25/19	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0
03/01/19	2	0	0	0	0	0	0	0	0	0	3	0	0	0	0	0	0	0	0	0	0	0	4	0
Baseline Data			0	0						0			0	0					0				0	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments

04/14/21	The fluid is in a reasonable condition. Low boiler vapor content (GCD% <335C.) is slightly high at 5.89% (fresh = 1%). This can be lowered by venting the vapors to atmosphere. The 90% GCD temperature is high which indicates degradation of the fluid by oxidation. The sample was taken mainly to look at Pentane Insolubles (solids) content of the fluid to determine whether one cleaning run is sufficient for cleaning of the system which will take place during the week of May 31st. The solids content hasn't changed significantly since January 2020 and therefore one cleaning run is still recommended. (GCD) 90% Distillation Point is abnormally high.
01/31/20	The fluid is in a similar condition as it was in March of 2019. The Flash Point is low and low boiler vapor content (GCD% <335C.) has increased. These are indications of thermal degradation. The Pentane Insoluble (solids) content of the fluid has increased but is still sufficiently low to clean the system with one cleaning run followed by a flush. COC Flash Point is severely low.
03/25/19	COC Flash point is low indicating that venting of the system to expel low boils is required. Vent system safely and resample. COC Flash Point is severely low.
03/01/19	Cleveland open cup Flashpoint and GCD 10% are very low and GCD 335°C is slightly high. Venting of heat transfer system to eliminate light ends is part of good fluid maintenance. Vent system and resample in 6 months. COC Flash Point is severely low. (GCD) 10% Distillation Point is abnormally low. (GCD) % < 335°C is marginally high.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.