

## [02-11-60-04W6] H-802 Peyto Kakwa

**Customer: PTRHTF20175**  
 QUADRA CHEMICALS  
 7802 98 STREET  
 CLAIRMONT, AB T0H 0W0 Canada  
 Attn: Quadra Samples  
 Tel:  
 E-Mail: quadra\_samples@quadra.ca




**System Information**  
 System Volume: 30000 ltr  
 Bulk Operating Temp: 752F / 400C  
 Heating Source:  
 Blanket:  
 Fluid: PETRO CANADA PETRO-THERM  
 Make: ALCO


**Sample Information**  
 Lab No: 02436099  
 Analyst: Clinton Buhler  
 Sample Date: 07/20/21  
 Received Date: 08/10/21  
 Completed: 08/11/21  
 Clinton Buhler  
 Clinton.Buhler@hollyfrontier.com

Recommendation: This appears to be the first sample taken since the system cleaning and fluid replacement that Peyto executed the week of July 12, 2021. Fluid condition has drastically changed for the better since this work: Fluid viscosity, solids content and acid number are back closer to like new levels. There is some indication of small amounts of residual degraded fluid remaining behind (slightly elevated flash point, 10 and 90% GCD temperature and viscosity (although this is vastly improved)). Please re-sample in 1 months time to help establish a trend for the fluid. Please ensure that blanket gas is operational above the fluid level in the expansion tank to help protect the fluid from oxidation in the future.

Comments: (GCD) 90% Distillation Point is marginally high.




Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
07/20/21	08/10/21	0.0m	Discharge pump	464 / 240	25.3	35.8	0.03	0.071	742 / 394	820 / 438	922 / 495	0.00
04/21/21	05/21/21	6.0m	Discharge after pump	459 / 237	21.2	112	0.88	1.60	735 / 391	820 / 438	920 / 494	0.47
01/18/21	02/04/21	3.0m	Pump discharge	453 / 234	0.7	104	0.61	1.94	743 / 395	829 / 443	911 / 488	0.00
10/30/20	11/20/20	0.1m	24 hour sample	460 / 238	51.6	110	0.44	2.15	745 / 396	833 / 445	922 / 494	0.00
07/06/20	10/13/20	0.0m	FILTER INLET	486 / 252	545.9		1.53	7.07	769 / 409	845 / 452	898 / 481	0.89
<b>Baseline Data</b>				433 / 223		34.2	0.03		720 / 382	817 / 436	900 / 482	1.00





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
07/20/21	7	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	3
04/21/21	142	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	1	0	2	2
01/18/21	151	0	0	0	0	0	0	0	0	0	0	0	14	0	0	0	1	0	0	0	1	0	2	2
10/30/20	164	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	1	0	1	0	2	2
07/06/20	52	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Baseline Data			0	0						0			0	0				0					0	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments	
04/21/21	Sample results indicate continued fluid oxidation; see Acid Number and viscosity increases. Solids content remains high. It is advised to perform a system cleaning and fluid replacement. Please ensure that expansion tank blanket gas is properly operational.
01/18/21	Sample results indicate that the fluid has maintained similar condition to the previous sample taken 3 months prior which was taken 24 hours after the system was sweetened. Fluid viscosity remains over 3x that of fresh fluid and Acid Number and Solids content remain elevated. It is advised to continue to make plans to clean system and re-fill with fresh fluid during warmer months. Please re-sample in 3 months. Pentane Insolubles levels are severely high. Visc @ 40°C is severely high. Acid Number (AN) is abnormally high.
10/30/20	The sweetening of the system has improved the condition of the fluid. Viscosity is now measurable but is quite high at 110cSt and needs to be closely monitored. The sweetening of the system has also brought down the fluid's Acid Number and Solids content although solids is still high. Please ensure blanket is set between 2-3 psi. Continue to make plans for system cleaning in 2021. Please re-sample system on or after December 30, 2020 so we can continue to trend iron ppm levels are marginal. Pentane Insolubles levels are severely high. Visc @ 40°C is severely high. Acid Number (AN) is abnormally high. (GCD) 90% Distillation Point is marginally high.
07/06/20	This fluid is heavily oxidized. Pentane Insolubles are at 7.07, viscosity is too high to measure, and acid number is severely high. Fluid needs to be changed. Pentane Insolubles levels are severely high. Water contamination levels are marginally high. Water contamination levels are marginally high. ppm Water contamination levels are marginally high. Acid Number (AN) is severely high. (GCD) 10% Distillation Point is abnormally high. (GCD) 50% Distillation Point is marginally high. Viscosity is too high to measure.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.