



ASPHALT TANK FARM


Customer: PTRHTF10051	System Information	Sample Information
SUPERIOR READY MIX	System Volume: 500 gal	Lab No: 02436778
1508 MISSION RD	Bulk Operating Temp: 380F / 193C	Analyst: Ron LeBlanc
ESCONDIDO, CA 92029 USA	Heating Source:	Sample Date: 07/19/21
Attn: MARK STROMEYER	Blanket:	Received Date: 08/04/21
Tel: (760)745-0556	Fluid: PETRO CANADA PETRO-THERM	Completed: 08/10/21
E-Mail: purchasing@superiorrm.com	Make: HEATEC	Ron LeBlanc
		Ronald.LeBlancSr@hollyfrontier.com

Recommendation: The calcium content is very high. Acid Number is very high indicating oxidation which can cause sludge deposits and system corrosion. Oxidation is confirmed by the viscosity increase reported. Viscosity increase indicates the presence of high boilers (oxidation) which reduces the fluids ability to transfer heat. The pentane insolubles indicate deposits that are in the oil. The (GCD) 90% indicates components boiling above the fresh fluid limits which can foul heat exchanger surfaces. This oil is at the end of useful life and should be cleaned, flushed and refilled with new oil.

Comments: Pentane Insolubles levels are severely high. Acid Number (AN) is severely high. Calcium ppm levels are severely high. Visc @ 40°C is severely high. (GCD) 90% Distillation Point is abnormally high.







Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.