



LINE 1


Customer: PTRHTF10249	System Information	Sample Information
BONDED LOGIC	System Volume: 200 gal	Lab No: 02446366
1465 SHATTUCK INDUSTRIAL BLVD	Bulk Operating Temp: 425F / 218C	Analyst: Jake Finn
LAFAYETTE, GA 30728 USA	Heating Source:	Sample Date: 09/20/21
Attn: Donny Walls	Blanket:	Received Date: 09/27/21
Tel:	Fluid: PETRO CANADA PETRO-THERM	Completed: 10/05/21
E-Mail: donnyw@bondedlogic.com	Make:	Jake Finn
		jake.finn@hollyfrontier.com

Recommendation: High acid number and low flash point indicate the fluid in system has experienced some oxidation. There is no current indication of system component wear or contamination, but if system remains as is, it could result in corroded parts or component wear. Recommended to drain system and refill with fresh Petro-Therm, followed by regular oil analysis every 12 months. If possible, also perform visual inspection of system when fluid is replaced.

Comments: Acid Number (AN) is abnormally high. COC Flash Point is marginally low.







Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.

Report ID: [02446366] (Generated: 11/15/2021 16:07:08) - Page 2 - Copyright 2021 Wearcheck Inc. All Rights Reserved.