



## HEATING OIL 21

Customer:	System Information	Sample Information
KNOLL NORTH AMERICAN CORP. 1000 ARROW ROAD TORONTO, ON M9M 2Y7 Canada Attn: Magdi Killzi Tel: (416)401-6054 E-Mail: mkillzi@knoll.com	System Volume: 0 gal Bulk Operating Temp: Not Specified Heating Source: Blanket: Fluid: NOCO NOCO HEAT TRANSFER OIL 21 Make:	Lab No: 02446730 Analyst: Bill Quesnel CLS,OMA II,MLA-III,LLA-I Sample Date: 09/15/21 Received Date: 09/28/21 Completed: 10/04/21 Bill Quesnel CLS,OMA II,MLA-III,LLA-I

Recommendation: This is a baseline read-out on the submitted sample.

Comments: {not applicable} {not applicable} {not applicable}

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
09/15/21	09/28/21	0.0h	HEATING OIL 21	475 / 246	150.3	40.9	0.02	0.124	772 / 411	846 / 452	927 / 497	0.00
Baseline Data				468 / 242		50.2			772 / 411	846 / 452	927 / 497	0.0



