



GFPT-FUTHER 2/1

Customer: PTRHTF60010	System Information	Sample Information
SYNLUBE INTERNATIONAL CO LTD 76/1 MOO.7 THACHIN MUANG SAMUTSAKHON, 74000 THAILAND Attn: CHERNPORN CHOBKUI Tel: 034421290 E-Mail: chernporn@synlube.co.th	System Volume: 21525 ltr Bulk Operating Temp: 554F / 290C Heating Source: Blanket: Fluid: PETRO CANADA PURITY FG HEAT TRANSFER FLUID Make:	Lab No: 02448260 Analyst: Philip Riley Sample Date: 09/22/21 Received Date: 10/05/21 Completed: 10/07/21 Philip Riley philip.riley@hollyfrontier.com

Recommendation: Oil in good condition and fit for further use. Please resample at normal frequency

Comments: (GCD) 90% Distillation Point is abnormally high.

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
09/22/21	10/05/21	4.0m		406 / 208	24.8	30.1	0.66	0.074	706 / 374	819 / 437	924 / 495	3.84
Baseline Data				459 / 237		37.12	0.90		721 / 383	807 / 431	892 / 478	1.5



