




APP-TOX



Customer: PTRHTF10059	System Information	Sample Information
CERTAINTEED - SAINT GOBAIN 11519 US RT 250 N MILAN, OH 44846 USA Attn: DAVE BLAKELY Tel: (419)541-0843 E-Mail: dave.l.blakely@saint-gobain.com	System Volume: 8875 gal Bulk Operating Temp: 500F / 260C Heating Source: Blanket: Fluid: PETRO CANADA CALFLO AF Make: JOHN ZINK	Lab No: 02448265 Analyst: Yvette Trzcinski Sample Date: 09/17/21 Received Date: 10/05/21 Completed: 10/08/21 Yvette Trzcinski yvette.trzcinski@hollyfrontier.com

Recommendation: Flash point and viscosity are within acceptable ranges, the acid number has improved from the last sample as well as the solids amount - looks like there was some make up added to the system. The GDC 90% is slightly high but is fairly consistent over the last 3 samples. Product is acceptable for continued use and resample in 6 - 12 months

Comments: Acid Number (AN) is abnormally high. (GCD) 90% Distillation Point is marginally high.




Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
09/17/21	10/05/21	36.0m	SAMPLE PORT	439 / 226	26.3	32.3	0.32	0.158	710 / 377	806 / 430	911 / 488	1.01
02/15/21	02/25/21	14.0m	Sample port	428 / 220	9.4	34.2	0.41	0.270	708 / 376	807 / 431	914 / 490	1.20
07/28/20	08/05/20	8.0m	NEW SYSTEM	435 / 224	28.1	32.7	0.47	0.093	714 / 379	808 / 431	913 / 489	0.72
Baseline Data				435 / 224		32.7	0.03		693 / 367	790 / 421	887 / 475	2.5





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc		
09/17/21	44	0	0	0	0	0	0	0	0	0	0	2	0	0	0	0	0	0	0	0	0	0	0	246	2	
02/15/21	56	0	0	0	0	0	0	0	0	0	1	1	0	0	0	0	0	0	0	0	0	0	0	0	240	3
07/28/20	13	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	247	2
Baseline Data			0	0						0			0	0					0					270		

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments	
02/15/21	The total acid number is high but the acid number and GCD 90% and flash point have remained consistent from the last sample. The solids have more than doubled and there is a slight increase in viscosity which could be due to degradation in the system and contamination. Continue to monitor and resample in 6 months
07/28/20	This is a new system that was brought on line in December 2019 - filled with new Calflo AF heat transfer oil. The total acid number is very high for oil that has been in service for 7 - 8 months. The viscosity flash point are acceptable for service. the system was not flushed before filling with the fluid, please resample in 3-4 months to monitor the system Acid Number (AN) is abnormally high. (GCD) 90% Distillation Point is marginally high.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.