

[ATHABASCA OIL CORP / 08-28-078-10W4M] L4 (PAD D) LIESMER

Customer: PTRHTF20133

ATHABASCA OIL CORP.

LEISMER DEMONSTRATION PLANT

LSD2-79-10-W4M

NEAR CONKLIN, AB Canada

Attn: George Ball Tel: (587)233-1312 E-Mail: gball@atha.com

System Information

System Volume: 8000 ltr

Bulk Operating Temp: 212F / 100C

Heating Source:

Blanket:

Fluid: PETRO CANADA CALFLO LT Make: TORNADO TECHNOLOGIES

Sample Information

Lab No: 02470276 Analyst: Terry Veenstra Sample Date: 01/21/22 Received Date: 02/04/22 Completed: 02/07/22


Terry Veenstra

terry.veenstra@hollyfrontier.com


Recommendation: Fluid is in good condition and suitable for continued use. Resample in 6 months.

Comments:

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	%06 QO5	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
01/21/22	02/04/22	0.0y	system header	345 / 174	4.4	7.7	0.07	0.014	611 / 321	642 / 339	735 / 391	44.04
07/29/21	08/10/21	0.0y	pit 12d-0285	356 / 180	10.3	7.5	0.06	0.035	613 / 323	642 / 339	733 / 390	40.73
02/03/21	02/24/21	0.0y	Bott. of tracer tree	354 / 179	25.3	7.6	0.07	0.095	612 / 322	642 / 339	738 / 392	42.98
08/12/20	08/31/20	0.0y	PT0285	349 / 176	7.3	7.7	0.07	0.037	612 / 322	643 / 339	736 / 391	42.85
01/16/20	02/10/20	0.0y	HORM-12D-0008-001	356 / 180	0.00	7.6	0.060	0.032	606 / 319	652 / 345	747 / 397	33.68
Baseline Data				349 / 176		7.52	0.1		604 / 318	640 / 338	734 / 390	47.0







Historical Comments							
07/29/21	Fluid is in good condition and is suitable for continued use. Resample in 6 months.						
02/03/21	Fluid is in good condition and good for continued use. Resample in 6 months						
08/12/20	The presence of metal fines may indicate process pump, mechanical seal, or valve wear. Pipe slag, bits of welding beads, sand, etc. are commonly found: a) in new systems after startup, or b) in older systems that have not been filtered. Insoluble solids measurements in excess of 50mg solids/100ml fluids, and especially in excess of 250mg solids/100ml fluids of particles above 10pm, call for installation of slip-stream filtration in the system where a modest pressure drop is available to filter a low flow slip stream (less than 19% of the main flow rate). This will minimize wear on mechanical components such as pumps and valves. While the sample has shown low or negligible elemental (Wear Metal) results, the system can benefit from early intervention with a low flow, off-line (aka kidney-loop) filtration procedure. Resample after filtration.						
01/16/20	Resample at the next scheduled interval. Wear metals are low. Contaminant level low. Fluid is in good condition.						

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.