



## METRO M.D.F. CO., LTD


Customer: PTRHTF60010	System Information	Sample Information
SYNLUBE INTERNATIONAL CO LTD	System Volume: 230000 ltr	Lab No: 02477391
76/1 MOO.7 THACHIN	Bulk Operating Temp: 536F / 280C	Analyst: Philip Riley
MUANG SAMUTSAKHON, 74000	Heating Source:	Sample Date: 02/10/22
THAILAND	Blanket:	Received Date: 03/15/22
Attn: CHERNPORN CHOBKUI	Fluid: TOTAL SERIOLA 1510	Completed: 03/21/22
Tel: 034421290	Make:	Philip Riley
E-Mail: chernporn@synlube.co.th		philip.riley@hollyfrontier.com

Recommendation: Unfamiliar with the specific chemistry as competitor fluid, however, there is clear evidence of fluid breakdown. The pentane insoluble are high, and the viscosity has reduced approx. 20% from fresh oil value. You need to look towards a scheduled fluid change with clean and flush, replacement would be CALFLO HTF

Comments: Pentane Insolubles levels are abnormally high. (GCD) % < 335°C is marginally high. (GCD) 10% Distillation Point is marginally low. COC Flash Point is marginally low.







Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.

Report ID: [02477391] (Generated: 03/21/2022 11:02:20) - Page 2 - Copyright 2022 Wearcheck Inc. All Rights Reserved.