

LINE 3

Customer: PTRHTF60002

BOYNE SMELTERS LTD-RIO TINTO HANDLEY DRIVE **QUEENSLAND BOYNE ISLAND, QUE 4680**

AUSTRALIA

Attn: Heath Mitchell

Tel:

System Information

System Volume: 1500 ltr

Bulk Operating Temp: 419F / 215C

Heating Source:

Blanket:

Fluid: PETRO CANADA CALFLO AF

Make:

Sample Information

Lab No: 02493027 Analyst: Philip Riley Sample Date: 05/27/22 Received Date: 06/07/22 Completed: 06/14/22


Philip Riley

philip.riley@hollyfrontier.com


Recommendation: All parameters meet expected criteria. Please sample at normal frequency

Comments:

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	%06 GCD	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
05/27/22	06/07/22	0.0y		414 / 212	14.3	29.6	0.07	0.034	694 / 368	797 / 425	899 / 482	2.75
11/23/21	12/07/21	0.0y		428 / 220	11.4	29.7	0.08	0.077	696 / 369	797 / 425	898 / 481	2.17
11/23/20	12/17/20	20.0y	rtrn b4 gas burner	432 / 222	23.7	29.8	0.07	0.074	698 / 370	798 / 425	899 / 482	1.70
03/31/20	07/07/20	20.0y	NEAR RETURN	421 / 216	19.2	29.8	0.06	0.161	697 / 369	798 / 425	898 / 481	2.22
01/10/18	01/23/18	10.0y		396 / 202	2.6	30.0	0.078	0.038	691 / 366	784 / 418	888 / 476	0.00
Baseline Data				435 / 224		32.7	0.03		693 / 367	790 / 421	887 / 475	2.5







Historical Comments							
11/23/21	Oil in good condition and fit for further use. Meets all expected parameters. Please resample at normal frequency						
11/23/20	Unlike the sample from line 1/2, this fluid looks to be in overall good condition. I note the different operating temperatures and this will influence that for sure, with this product operating 50C lower. There is a little evidence of cracking on the GCD curve but nothing substantial. The fluid meets all parameters expected and is fit for further use.						
03/31/20	All parameters meet specification with no concerns. Please resample at normal frequency						
01/10/18	The current fluid condition is very similar to the last sample in July 2017. The fluid has normal viscosity, flash point and distillation point. The water and solid contamination is low. Please continue to run this fluid and take one sample in 12 months.						

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.