


B150 GROEN


Customer: PTRHTF10078	System Information	Sample Information
WEST FORK CREATIONS	System Volume: 55 gal	Lab No: 02503192
15 PEPSI DRIVE	Bulk Operating Temp: 475F / 246C	Analyst: Ron LeBlanc
RED LODGE, MT 59068 USA	Heating Source:	Sample Date: 04/12/22
Attn: Becky Rietz	Blanket:	Received Date: 08/03/22
Tel: (406)426-3060	Fluid: PETRO CANADA PURITY FG HEAT TRANSFER FLUID	Completed: 08/04/22
E-Mail: foodsafety@kingscupboard.com	Make: STERLCO	Ron LeBlanc
		Ronald.LeBlancSr@hollyfrontier.com

Recommendation: Decreased Viscosity:Lower viscosity oil added possibly.Indicates thermal degradation.IMPROVES THE FLUID'S ABILITY TO TRANSFER HEATBUT often reduces flash, fire and auto-ignition pointsThe GCD profile indicates cracking of the fluid. The lowered flash point coincides with cracking. You might try venting the expansion tank to remove the lighter fractions. Sample in 1 month.

Comments: COC Flash Point is severely low. Visc @ 40°C is abnormally low. (GCD) % < 335°C is marginally high. (GCD) 10% Distillation Point is marginally low.

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
04/12/22	08/03/22	12.0m	drain plug	331 / 166	38.4	25.3	0.51	0.328	655 / 346	798 / 426	893 / 478	8.10
10/29/20	11/11/20	0.0m	Drain	327 / 164	31.6	26.8	0.75	0.250	667 / 353	800 / 427	888 / 475	7.26
08/22/19	09/06/19	6.0m	DRAIN	410 / 210	0.00	29.0	0.557	0.223	690 / 366	803 / 429	888 / 476	4.50
07/22/19	08/01/19	0.8m	DRAIN VALVE	313 / 156	20.9	28.7	0.521	0.185	690 / 366	801 / 427	885 / 474	4.31
06/28/18	07/23/18	5.0m	OIL DRAIN	349 / 176	78.3	30.8	0.905	1.24	685 / 363	803 / 428	897 / 481	5.51





07/22/19 The oil could have been overheated or severely taken up to operating temperature rapidly. Viscosity has dropped significantly in the last 2 samples. If possible add fresh oil to bring viscosity and COC Flash Point up. Take another sample and send in to verify results. COC Flash Point is severely low. Pentane Insolubles levels are severely high. COC Flash Point is severely low. A small charge of new oil can bring the COC flash point up. Resample and purge

06/28/18 Pentane insolubles levels are severely high. COC Flash Point is severely low. A small charge of new oil can bring the COC flash point up. Resample and purge extra oil out of sample port to get a good sample to confirm numbers. Pentane Insolubles levels are severely high. COC Flash Point is severely low.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.