




## [Tourmaline / 3-16-60-02W6] HEAT MEDIUM


Customer: PTRHTF20175	System Information	Sample Information
QUADRA CHEMICALS 7802 98 STREET CLAIRMONT, AB T0H 0W0 Canada Attn: Quadra Samples Tel: E-Mail: quadra_samples@quadra.ca	System Volume: 23000 ltr Bulk Operating Temp: 374F / 190C Heating Source: Blanket: Fluid: PETRO CANADA PETRO-THERM Make: HTH HEATECH INC	Lab No: 02506732 Analyst: Clinton Buhler Sample Date: 08/04/22 Received Date: 08/23/22 Completed: 08/26/22 Clinton Buhler Clinton.Buhler@hollyfrontier.com

Recommendation: Sample results indicate that the fluid is in suitable condition for continued service. Please re-sample after 12 months of continued runtime.

Comments:




Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
08/04/22	08/23/22	52.0m	PUMP BLEED	439 / 226	133.5	34.8	0.10	0.009	733 / 389	815 / 435	915 / 491	0.00
01/24/22	02/22/22	45.0m	Pump bleed	442 / 228	97.5	35.1	0.01	0.030	732 / 389	816 / 435	916 / 491	0.04
01/26/21	02/04/21	34.0m	Pump bleed	460 / 238	88.8	35.2	0.03	0.062	732 / 389	815 / 435	917 / 492	0.00
01/27/20	02/24/20	21.0m	PUMP BLEED	453 / 234	18.1	35.4	0.048	0.057	701 / 372	783 / 417	882 / 472	0.00
06/03/19	07/02/19	15.0m	PUMP BLEED	442 / 228	7.0	35.0	0.026	0.052	715 / 380	802 / 428	910 / 488	1.25
Baseline Data				433 / 223		34.2	0.03		720 / 382	817 / 436	900 / 482	1.00





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
08/04/22	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
01/24/22	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
01/26/21	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0
01/27/20	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
06/03/19	2	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	1	0	0	0
Baseline Data			0	0						0			0	0					0				0	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



### Historical Comments

01/24/22	Sample results indicate that the fluid is in suitable condition for continued service. Please re-sample in 12 months.
01/26/21	Sample results indicate that the heat transfer fluid is in suitable condition for continued service; fluid is in very healthy condition. Please re-sample in one year.
01/27/20	Sample results indicate that the fluid is suitable for continued service. Please re-sample in 12 months
06/03/19	Sample results indicate that the heat transfer fluid is suitable for continued service. Please re-sample in 12 months

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.