

HEATTRANSFER

Customer: PTRHTF20218

McAsphalt Industries 61065 TWP 730 Clairmont, AB T8X 0T8 Canada

Attn: Jim Reid Tel: (780)567-2145

E-Mail: jreid@mcasphalt.com

System Information

System Volume: 0 ltr

Bulk Operating Temp: 400F / 204C

Heating Source:

Blanket:

Fluid: PETRO CANADA PETRO-THERM

Make: CEI


Sample Information


Lab No: 02509198 Analyst: Peter Harteveld Sample Date: 04/27/22 Received Date: 09/06/22 Completed: 09/12/22 Peter Harteveld

peter.harteveld@hollyfrontier.com

Recommendation: With the exception of the acid number (AN) the fluid is in a near fresh condition. Since the test method for AN is not the most accurate and there is no corrosion taking place, (Fe is at 2 ppm.) the AN can be ignored. The fluid is suitable for use. Please re-sample in 6 months.

Comments: Acid Number (AN) is abnormally high.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.