

# 451-ACHESON RAIL

**Customer: PTRHTF20056**  
 McAsphalt  
 26222 TOWNSHIP ROAD 530A  
 ACHESON, AB T7X 5A7 Canada  
 Attn: Luis Salinas  
 Tel: (780)699-2447  
 E-Mail: lsalinas@mcasphalt.com




**System Information**  
 System Volume: 4000 ltr  
 Bulk Operating Temp: Not Specified  
 Heating Source:  
 Blanket:  
 Fluid: PETRO CANADA PETRO-THERM  
 Make: HEATEC



**Sample Information**  
 Lab No: 02509199  
 Analyst: Yutong Gao  
 Sample Date: 08/28/22  
 Received Date: 09/06/22  
 Completed: 09/13/22  
 Yutong Gao  
 yutong.gao@HFSinclair.com

Recommendation: The current fluid has adequate viscosity, flash point and distillation points. However, the high TAN suggests the fluid has oxidation. The 0.9% solid content is extremely high which is most likely resulted from the fluid oxidation. Please find opportunity to filter the solid out in the near future. If the cost of filtration work is too high or there is no time for the filtration work, then please plan a fluid change soon.

Comments: Solid levels are severely high. Acid Number (AN) is severely high.




Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
08/28/22	09/06/22	0.0y		421 / 216	125.0	37.1	0.66	0.900	731 / 388	815 / 435	911 / 488	0.72
06/04/19	07/12/19	2.5y		435 / 224	23.1	36.9	0.969	0.120	722 / 384	808 / 431	906 / 486	0.00
Baseline Data				433 / 223		34.2	0.03		720 / 382	817 / 436	900 / 482	1.00





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
08/28/22	87	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	0	0	0	4	0	4	0
06/04/19	27	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	9	0	2	0
Baseline Data			0	0						0			0	0					0				0	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments	
06/04/19	the Acid Number and Pentane insoluble are slightly high, and as result, the viscosity at 40 is higher than the ISO 32. need to monitor the iron level in the oil closely and make sure there is no internal corrosion. Acid Number (AN) is severely high.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.