

CALFLO HTF



Petro-Canada Technical/Yen Garcia

Mississauga, ON L5J 1K2 Canada

Attn: Yen Garcia

Tel:

E-Mail: yen.garcia@hfsinclair.com

System Information

System Volume: 0 gal

Bulk Operating Temp: Not Specified

Heating Source:

Blanket:

Fluid: PETRO CANADA CALFLO AF

Make: EXPANSION TANK

Sample Information

Lab No: 02514417 Analyst: Yen Garcia Sample Date: 09/28/22 Received Date: 10/04/22 Completed: 12/14/22


Yen Garcia

yen.garcia@HFSinclair.com

Recommendation: We have been unable to identify the customer that sent this sample, but we suspect that was Panolam, Huntsville and that the sample could have been taken from the expansion tank. If the sample belongs to Panolam they are already aware of the oil condition and the need to replace it.

Comments: (GCD) % < 335°C is severely high. Acid Number (AN) is severely high. (GCD) 50% Distillation Point is severely low. (GCD) 90% Distillation Point is severely low. Visc @ 40°C is severely low. (GCD) 10% Distillation Point is abnormally low. COC Flash Point is abnormally low.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.