




LINE 7 HOT OIL SYSTEM


Customer: PTRHTF10094	System Information	Sample Information
CERTAINEED CORPORATION - OXFORD 200 CERTAINEED RD OXFORD, NC 27565 USA Attn: Seth Newton Tel: (919)693-1141 E-Mail: Seth.newton@saint-gobain.com	System Volume: 375 gal Bulk Operating Temp: 519F / 271C Heating Source: Blanket: Fluid: PETRO CANADA PETRO-THERM Make:	Lab No: 02515789 Analyst: Manny Garcia Sample Date: 09/22/22 Received Date: 10/12/22 Completed: 10/17/22 Manny Garcia manuel.garcia@HFSinclair.com

Recommendation: Recommendation to 'vent' this system to mitigate the low COC flash point value and re-submit sample to verify increase in value.

Comments: This fluid has a lower than expected COC Flash Point for a 12-month old fluid. We recommend 'venting' the system to correct this 168oC flash point in order to improve it to the 200oC or better range. All of the other parameters are in above satisfactory limits.




Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F / °C	ppm	cSt	mg/KOH/g	%wt	°F / °C	°F / °C	°F / °C	%
09/22/22	10/12/22	12.0m	AFTER HEATER	334 / 168	5.9	28.8	0.09	0.104	693 / 367	802 / 428	904 / 485	4.50
10/01/21	10/18/21	0.0m	by supply pump	367 / 186	23.1	27.6	0.05	0.033	689 / 365	799 / 426	902 / 483	4.79
05/12/20	07/06/20	5.0m		399 / 204	11.6	28.4	0.10	0.159	688 / 365	799 / 426	902 / 483	4.95
04/10/19	04/22/19	48.0m	HEATER	405 / 207	3.7	28.6	0.040	0.049	687 / 364	795 / 424	904 / 485	4.09
02/07/19	02/28/19	1.0m	HOT OIL HEATER	342 / 172	22.8	28.6	0.054	0.019	647 / 341	771 / 411	881 / 472	8.39
Baseline Data				433 / 223		34.2	0.03		720 / 382	817 / 436	900 / 482	1.00





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc	
09/22/22	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
10/01/21	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
05/12/20	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04/10/19	7	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
02/07/19	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Baseline Data			0	0						0			0	0					0				0		

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments	
10/01/21	Oil is suitable for continued use. Recommend next sample be submitted in October 2022. COC Flash point is down 180c to 186 oC & should be monitored closely.
05/12/20	Virtually no change to the fluid in the last year. Viscosity is stable, flash point remains strong, no asphalt or moisture contamination. No action required based on these results.
04/10/19	The significant oil addition is noticed by the improved GCD results. No action required at this time. Re-sample this system at the next scheduled interval.
02/07/19	Last year we suggested some venting to bring the viscosity and flash point up. The flash point further decreased and low boilers increased some more. We are suggesting venting as well as replacing about 10% of the system fluid with fresh oil to help accelerate the improvement in the condition of the overall fluid. Once the venting and partial oil replacement has been done we recommend to take another sample a couple days later to measure the impact. COC Flash Point is abnormally low. (GCD) 10% Distillation Point is abnormally low. (GCD) % < 335°C is marginally high. (GCD) 90% Distillation Point is marginally low.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.