




MORA HE



| Customer: PTRHTF40043 | System Information | Sample Information |
|---|---|--|
| MORA PRODUCTIE BV FREGATWEG 53 MAASTRICHT 6222NZ MAASTRICHT, 6222NZ Netherlands Attn: WILBERT SNIJERS Tel: E-Mail: w.snijers@klt.nl | System Volume: 800 ltr Bulk Operating Temp: 300F / 149C Heating Source: Blanket: Fluid: PETRO CANADA PURITY FG HEAT TRANSFER FLUID Make: | Lab No: 02516482 Analyst: Bill Quesnel CLS,OMA II,MLA-III,LLA-I Sample Date: 10/11/22 Received Date: 10/17/22 Completed: 10/19/22 Bill Quesnel CLS,OMA II,MLA-III,LLA-I |

Recommendation: COC Flash Point is low. Suggest venting the expansion tank. Resample at the next normal interval.

Comments: Iron ppm levels are abnormal. Pentane Insolubles levels are abnormally high. COC Flash Point is abnormally low. (GCD) 90% Distillation Point is marginally high.




| Sample Date | Received Date | Fluid Age | Sample Location | Flash Point (COC) | Water (KF) | Viscosity (40°C) | Acid Number | Solids | GCD 10% | GCD 50% | GCD 90% | GCD % < 335°C |
|---------------|---------------|-----------|-----------------|-------------------|------------|------------------|-------------|--------|-----------|-----------|-----------|---------------|
| | mm/dd/yy | | | °F/°C | ppm | cSt | mg/KOH/g | %wt | °F/°C | °F/°C | °F/°C | % |
| 10/11/22 | 10/17/22 | 3.8y | | 365 / 185 | 12.2 | 32.9 | 0.76 | 0.445 | 713 / 378 | 812 / 434 | 912 / 489 | 2.72 |
| 04/05/22 | 04/12/22 | 3.3y | | 399 / 204 | 31.6 | 32.8 | 0.79 | 0.141 | 711 / 377 | 813 / 434 | 916 / 491 | 2.96 |
| 09/21/21 | 09/27/21 | 32.0y | | 385 / 196 | 20.3 | 32.3 | 0.66 | 0.199 | 711 / 377 | 812 / 433 | 911 / 489 | 2.85 |
| 03/09/21 | 03/15/21 | 27.0y | | 417 / 214 | 29.4 | 32.2 | 0.88 | 0.244 | 698 / 370 | 804 / 429 | 918 / 492 | 3.82 |
| 09/01/20 | 09/09/20 | 18.0y | | 392 / 200 | 13.8 | 31.4 | 0.70 | 0.114 | 700 / 371 | 810 / 432 | 913 / 489 | 4.27 |
| Baseline Data | | | | 459 / 237 | | 37.12 | 0.90 | | 721 / 383 | 807 / 431 | 892 / 478 | 1.5 |





| Sample Date | Iron | Chromium | Nickel | Aluminum | Copper | Lead | Tin | Cadmium | Silver | Vanadium | Silicon | Sodium | Potassium | Titanium | Molybdenum | Antimony | Manganese | Lithium | Boron | Magnesium | Calcium | Barium | Phosphorus | Zinc |
|---------------|------|----------|--------|----------|--------|------|-----|---------|--------|----------|---------|--------|-----------|----------|------------|----------|-----------|---------|-------|-----------|---------|--------|------------|------|
| 10/11/22 | 209 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1 | 0 | 0 | 0 | 0 | 0 | 1 | 0 | 0 | 0 | 0 | 0 | 148 | 5 |
| 04/05/22 | 354 | 0 | 0 | 0 | 1 | 0 | 0 | 0 | 0 | 0 | 2 | 0 | 0 | 0 | 0 | 0 | 2 | 0 | 0 | 0 | 0 | 0 | 167 | 8 |
| 09/21/21 | 345 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2 | 0 | 0 | 0 | 0 | 0 | 2 | 0 | 0 | 0 | 1 | 0 | 173 | 10 |
| 03/09/21 | 416 | 0 | 0 | 0 | 1 | 0 | 0 | 0 | 0 | 0 | 2 | 1 | 2 | 0 | 0 | 0 | 3 | 0 | 0 | 0 | 1 | 0 | 187 | 11 |
| 09/01/20 | 225 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1 | 0 | 0 | 0 | 0 | 0 | 176 | 8 |
| Baseline Data | | | 0 | 0 | | | | | | 0 | | | 0 | 0 | | | | 0 | 0 | | | | 230 | |

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments

| | |
|----------|--|
| 04/05/22 | Likely the iron levels are from rust/scale present in the sample as a result of sampling from a low point in the system. Recommend resample in one year to monitor. Iron ppm levels are abnormal. (GCD) 90% Distillation Point is marginally high. COC Flash Point is marginally low. |
| 09/21/21 | Iron content keeps high. Is the sample taken correctly and really representative for the bulk of the system? The iron content cannot be explained with the TAN values that are OK. Otherwise the oil is fit for further use. PQ levels are severe. Iron ppm levels are abnormal. (GCD) 90% Distillation Point is marginally high. COC Flash Point is marginally low. |
| 03/09/21 | Iron content cannot be explained with the TAN values. If the system is new this could be a possible explanation, also for the previous results. Otherwise the oil is fit for further use. Iron ppm levels are severe. (GCD) 90% Distillation Point is marginally high. |
| 09/01/20 | High level of iron so please investigate the source if possible. Fit for further use and re-sample at next scheduled frequency as these are short frequencies with this system. Iron ppm levels are abnormal. (GCD) 90% Distillation Point is marginally high. COC Flash Point is marginally low. |

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.