


WANSON BH/INC 1200

| Customer: PTRHTF40127 | System Information | Sample Information |
|--------------------------------|---|---------------------------------------|
| Dalco Foods B.V | System Volume: 4200 gal | Lab No: 02528285 |
| Everdenberg 50 | Bulk Operating Temp: 518F / 270C | Analyst: Bill Quesnel CLS,OMA II,MLA- |
| Oosterhout, 4902TT Netherlands | Heating Source: | III,LLA-I |
| Attn: Wilbert Snijers | Blanket: | Sample Date: 12/05/22 |
| Tel: | Fluid: PETRO CANADA PURITY FG HEAT TRANSFER FLUID | Received Date: 12/12/22 |
| E-Mail: w.snijers@klt.nl | Make: WANSON | Completed: 12/20/22 |
| | | Bill Quesnel CLS,OMA II,MLA-III,LLA-I |


Recommendation: If expansion tank venting was carried out, this has successfully restored the flash point of the fluid. Vent expansion tank every three months to remove light ends from the fluid. Fluid is suitable for continued use. Resample at next normal interval to monitor.

Comments:

| Sample Date | Received Date | Fluid Age | Sample Location | Flash Point (COC) | Water (KF) | Viscosity (40°C) | Acid Number | Solids | GCD 10% | GCD 50% | GCD 90% | GCD % < 335°C |
|-------------|---------------|-----------|-----------------|-------------------|------------|------------------|--------------|--------|-----------|-----------|-----------|---------------|
| | mm/dd/yy | | | °F/°C | ppm | cSt | mg/KOH/ g | %wt | °F/°C | °F/°C | °F/°C | % |
| 12/05/22 | 12/12/22 | 1.0d | | 435 / 224 | 15.7 | 35.5 | 0.73 | 0.085 | 715 / 380 | 814 / 434 | 910 / 488 | 3.75 |
| 07/20/22 | 07/26/22 | 4.3d | | 342 / 172 | 31.5 | 23.4 | 0.32 | 0.233 | 619 / 326 | 793 / 423 | 897 / 481 | 10.48 |
| 01/13/22 | 01/20/22 | 3.8d | | 338 / 170 | 20.2 | 24.6 | 0.30 | 0.145 | 611 / 322 | 792 / 422 | 897 / 480 | 10.93 |
| 07/30/21 | 08/04/21 | 3.3d | | 313 / 156 | 26.1 | 25.1 | 0.32 | 0.136 | 647 / 341 | 797 / 425 | 896 / 480 | 8.86 |
| 04/07/21 | 04/13/21 | 3.0d | | 306 / 152 | 22.8 | 23.0 | 0.26 | 0.128 | 592 / 311 | 788 / 420 | 908 / 486 | 11.83 |







Historical Comments

| 07/20/22 | Flash Point (COC) is very low and off specification. Recommend venting the system in order to reduce number of low boilers and recover flash point. Recommend resampling in six months to monitor. COC Flash Point is severely low. (GCD) 10% Distillation Point is abnormally low. (GCD) % < 335°C is marginally high. |
|----------|---|
| 01/13/22 | Flash Point (COC) is very low and off specification. Recommend venting the system in order to reduce number of low boilers and recover flash point. Recommend resampling in six months to monitor. COC Flash Point is severely low. (GCD) 10% Distillation Point is abnormally low. (GCD) % < 335°C is marginally high. |
| 07/30/21 | Flash Point (COC) is very low and off specification. Recommend venting the system in order to reduce number of low boilers and recover flash point. COC Flash Point is severely low. (GCD) 10% Distillation Point is abnormally low. (GCD) % < 335°C is marginally high. |
| 04/07/21 | Flash Point continues to be very low. Viscosity has decreased and evidence of cracking of the oil. Viscosity reduction is consistent and the value is distant from what we expect to see, it supports the theory of lower viscosity molecules being produced. Please try safe venting and check for recovery. Several warnings now on flash point and if recovery attempts have failed, recommend to look towards change. (GCD) 10% Distillation Point is severely low. COC Flash Point is severely low. (GCD) % < 335°C is abnormally high. Visc @ 40°C is abnormally low. |
| | |

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.