

SKOKIE

Customer: PTRHTF10260

Builders Asphalt 4401 Roosevelt Road Hillsdale, IL 60162 USA Attn: Virgil Marksmaker

Tel:

E-Mail: marsmaker@gmail.com

System Information

System Volume: 500 gal

Bulk Operating Temp: 330F / 166C

Heating Source:

Blanket:

Fluid: EASTMAN THERMINOL 55

Make: HYWAY/GENCOR


Sample Information


Lab No: 02530451 Analyst: Yvette Trzcinski Sample Date: 11/23/22 Received Date: 12/22/22 Completed: 01/03/23 Yvette Trzcinski

yvette.trzcinski@HFSinclair.com

Recommendation: System is showing signs of fluid degradation and oxidation viscosity has increased and the acid number is abnormally high sign of oxidation in the system and can lead to sludge and deposit in the system as well as corrosion. Fluid is acceptable for continued use but I recommend sampling in 6 - 9 months

Comments: Acid Number (AN) is abnormally high. Visc @ 40°C is abnormally high. (GCD) 90% Distillation Point is marginally high.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.