

[6-18-72-7W5] P690A

Customer: PTRHTF20265

IPC CANADA LTD 6-18-72-7W5

SLAVE LAKE, AB T0G 2A0 Canada

Attn: Todd Laing Tel: (780)849-0635

E-Mail: todd.laing@international-

petroleum.com

System Information
System Volume: 3822 ltr

Bulk Operating Temp: 500F / 260C

Heating Source:

Blanket:

Fluid: PETRO CANADA PETRO-THERM

Make: PETRO-TECH HEATERS

Sample Information


Lab No: 02530737 Analyst: Clinton Buhler Sample Date: 12/27/22 Received Date: 12/28/22 Completed: 01/05/23

Clinton Buhler

Clinton.Buhler@HFSinclair.com

Recommendation: Unable to run GCD testing due to excessive water content of 5% free water. Please re-sample after a thorough purge of the sample valve and related tubing. Please ensure sample is drawn hot from pump discharge and not from a low lying area.


Comments:





Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]

GCD Spectrum



Historical Comments	
04/22/22	Sample Results indicate the fluid is in suitable condition for continued service. Please re-sample in 12 months (GCD) 90% Distillation Point is marginally high.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.