



Attn: Elaine Penner Tel: (250)567-8359 E-Mail: elaine.penner@canfor.com Bulk Operating Temp: 455F / 235C Heating Source: Blanket: Fluid: PETRO CANADA PETRO-THERM Make: DELTECH Lab No: 02532123 Analyst: Ray Rolston Sample Date: 01/01/23 Received Date: 01/09/23 Completed: 01/13/23 Ray Rolston Ray.Rolston@HFSinclair.com


Recommendation: The sample was not taken correctly; please submit another heat transfer fluid sample. Iron wear has increased from 25 ppm to 79 ppm likely due to a sampling anomaly. Water content was measured at 0.611% or 6,112 ppm compared with the previous samples of 32 ppm and 20.7 ppm with free water >10%. The Acid Number (AN) has almost doubled from 0.24 to 0.42 mg KOH/g which triggered a warning. Pentane Insolubles (solids) content has also increased from 0.092% on the previous sample to 0.211%. A simulated distillation (GCD) could not be run due to the high water content.


Comments: Water contamination levels are severely high. Water contamination levels are severely high.. ppm Water contamination levels are severely high. *** SimDis (GCD) not run due to high water content present in the sample *** Acid Number (AN) is abnormally high.

| Sample Date | Received Date | Fluid Age | Sample Location | Flash Point (COC) | Water (KF) | Viscosity (40°C) | Acid Number | Solids | GCD 10% | GCD 50% | GCD 90% | GCD % < 335°C |
|-------------|---------------|-----------|-------------------|-------------------|------------|------------------|--------------|--------|-----------|-----------|-----------|---------------|
| | mm/dd/yy | | | °F/°C | ppm | cSt | mg/KOH/ g | %wt | °F/°C | °F/°C | °F/°C | % |
| 01/01/23 | 01/09/23 | 13.0y | | 450 / 232 | 6112.2 | 36.0 | 0.42 | 0.211 | | | | |
| 11/18/21 | 12/03/21 | 11.0y | pipe before stack | 435 / 224 | 32.0 | 35.3 | 0.24 | 0.092 | 711 / 377 | 811 / 433 | 911 / 489 | 2.80 |
| 05/12/21 | 05/21/21 | 11.0y | Primary Pipe | 442 / 228 | 20.7 | 35.3 | 0.18 | 0.564 | 710 / 377 | 797 / 425 | 915 / 491 | 1.11 |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |









Historical Comments

| 11/18/21 | The iron content on this sample is 25 ppm compared with 8 ppm on the May 2021 sample. This may be due to differences in the way that the sample was obtained, or perhaps the sample was taken from a different location. Water content at 32 ppm and Acid Number (AN) at 0.24 mg KOH'g are low which is good. Cleveland Open Cup (COC), Flash Point and Gas Chromatograph Distillation (GCD) are good, although the Initial Boiling Point (IBP) is very low at 183 C (fresh = 316 C), and 2.8% GCD % < 335 C is elevated (fresh = 1%) indicating that some low boiler light fractions are present. Pentane Insolubles (solids content) has decreased from 0.564 wt% on the previous sample to 0.092 wt% suggesting that the oil has either been filtered, or a more representative sample was drawn. All other inspections are normal. Re-sample in 12 months to monitor |
|----------|--|
| 05/12/21 | Water content of sample was low at 20.7 ppm. Acid Number (AN) at 0.18 mg KOH/g is low which is good. COC Flash Point and GCD Distillation is good, although Initial Boiling Point (IBP) is a little low at 285 C indicating that some light fractions are present. Pentane Insolubles (solids) content is elevated at 0.564; the warning limit is 0.50%. Recommend investigating whether the heat transfer fluid can be filtered to remove this sediment. Re-sample in 6 months to monitor the fluid's condition. Pentane Insolubles levels are severely high |
| | |
| | |
| | |
| | |

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.