



## **MOKON OH0001**


Customer:	System Information	Sample Information
PYROWAVE	System Volume: 175 ltr	Lab No: 02532926
CP 174, SUCC. TOUR D/L BOURSE	Bulk Operating Temp: 347F / 175C	Analyst: Bill Quesnel CLS,OMA II,MLA-
MONTREAL, QC H4Z 1C8 Canada	Heating Source:	III,LLA-I
Attn: Laugane Patry	Blanket:	Sample Date: 01/04/23
Tel:	Fluid: PETRO CANADA CALFLO LT	Received Date: 01/12/23
E-Mail: lpatry@pyrowave.com	Make:	Completed: 01/31/23
		Bill Quesnel CLS,OMA II,MLA-III,LLA-I

Recommendation: The oil is near the end of it's useful service life, recommend schedule an oil change. We recommend an early resample to monitor this condition. Diagnostician's Note: The high acid number, and GCD @ 90% indicates a high level of oxidation of the fluid. The high viscosity supports this and also causes lower heat transfer efficiency in the system. Changing the fluid will improve heat transfer efficiency and lower operating costs.

Comments: There is no indication of any contamination in the fluid. Acid Number (AN) is severely high. (GCD) 90% Distillation Point is severely high. Visc @ 40°C is abnormally high. (GCD) 50% Distillation Point is marginally high. The fluid viscosity is higher than normal.







WearCheck Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it.

Report ID: [02532926] (Generated: 01/31/2023 12:12:36) - Page 2 - Copyright 2023 Wearcheck Inc. All Rights Reserved.