


	System volume. 29000 m	Lab NO. 02004000
12925 146TH STREET	Bulk Operating Temp: 320F / 160C	Analyst: Clinton Buhler
EDMONTON, AB T5L 2H6 CANADA	Heating Source:	Sample Date: 01/11/23
Attn: Quadra Samples	Blanket:	Received Date: 01/20/23
Tel:	Fluid: PETRO CANADA PETRO-THERM	Completed: 01/25/23
E-Mail: quadra_samples@quadra.ca	Make:	Clinton Buhler
		Clinton.Buhler@HFSinclair.com


Recommendation: Sample results indicate the fluid is in suitable condition for continued service. Water content is elevated, although lower than the last sample taken in 2018. Please vent off water vapor and take measures to reduce water ingression into the system. re-sample in 12 months.

## Comments:

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
01/11/23	01/20/23	0.0y	1279407-1	439 / 226	598.3	32.7	0.16	0.076	734 / 390	817 / 436	918 / 492	1.68
12/09/18	12/14/18	5.0y	PUMP SUCTION	439 / 226	1032.4	34.7	0.12	0.088	710 / 377	809 / 431	914 / 490	2.22








ື້ອີ 10,000

8,000

6,000

4,000

2.000



## **Historical Comments**

Percent Recovered

 The water content of the fluid is high. Please boil-off the water. Aside from the water the fluid is in good condition and suitable for further use. Please re-sample in 6 months.

 12/09/18

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.