

KONUS #1, 2 & 3

Customer: PTRHTF20179

Canfor - Polar 36654 Hart Highway General Delivery

Bear Lake, BC V0J 3G0 CA

Attn: Kevin Meise Tel: (250)552-5028

E-Mail: kevin.meise@canfor.com

System Information

System Volume: 140000 ltr

Bulk Operating Temp: 446F / 230C

Heating Source:

Blanket:

Fluid: PETRO CANADA PETRO-THERM

Make: KONUS

Sample Information

Lab No: 02534947 Analyst: Ray Rolston Sample Date: 01/16/23 Received Date: 01/23/23 Completed: 01/25/23


Ray Rolston


Ray.Rolston@HFSinclair.com


Recommendation: System was cleaned, flushed and recharged with Petro-Therm in May 2021. Iron wear has crept up to 29 ppm. All other wear metals are low. Water content is low at 20 ppm, and Acid Number (AN) is also low at 0.06 mg KOH/g. Gas Chromatography Distilllation (GCD) results are similar to fresh oil properties. Pentane Insolubles (solids) content is low at 0.088 wt%. All other inspections are normal; the fluid is in excellent condition. Recommend resampling in one year to monitor.


Comments:

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	%06 GCD	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
01/16/23	01/23/23	0.0y	pump #7	460 / 238	20.1	34.3	0.06	0.088	739 / 393	821 / 439	908 / 487	1.03
07/03/22	07/04/22	0.0y		428 / 220	30.1	34.1	0.03	0.081	732 / 389	819 / 437	908 / 486	1.80
10/04/21	10/13/21	0.5y	#7 pump gauge	446 / 230	45.3	34.7	0.06	0.147	734 / 390	815 / 435	905 / 485	0.47
05/24/21	05/31/21	0.0y	Gauge 7	460 / 238	29.8	35.0	0.05	0.044	728 / 387	807 / 431	913 / 489	0.00
05/23/21	05/31/21	0.0y	Pump 7 gauge	471 / 244	19.2	34.9	0.03	0.052	728 / 387	807 / 431	906 / 486	0.29
Baseline Data				433 / 223		34.2	0.03		720 / 382	817 / 436	900 / 482	1.00










Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]

0

Baseline Data



Historical Comments							
07/03/22	The Petro-Therm heat transfer fluid continues to be in 'like new' condition. The Acid Number (AN) remains low at 0.03mg KOH/g, and Pentane Insolubles (sludge) is also low at 0.081 wt%. All other fluid properties are in excellent condition. Recommend resampling in one year to monitor the fluid's condition.						
10/04/21	The Acid Number (AN) of the oil after 6 months in service remains low at 0.06 mg KOH/g. The KV40 viscosity is stable at 34.7 cSt. Cleveland Open Cup (COC) Flash Point is also stable at 230 deg C. Gas Chromatograph Distillation (GCD) results are very good. The Pentane Insolubles (solids) content has increased marginally to 0.147 wt%. Re-sample in one year to monitor the fluid's condition.						
05/24/21	Sample was submitted May 24, 2021 labelled KONUS #1, 2 & 3 Gauge 7. All test results on the fluid are as new. Water is 29.8 ppm; Acid Number is 0.05 mg KOH/g; Pentane Insolubles (solids) is 0.044 wt%. Recommend re-sampling in 6 months to monitor the fluid's condition.						
05/23/21	Sample was labelled KONUS #1, 2 & 3 Pump 7 gauge. All fluid properties are like new. Water content is 19.2 ppm; Acid Number 0.03 (previously 0.97 mg KOH/g); Pentane Insolubles 0.052 wt% (previously 2.14 wt%). Recommend sampling in 6 months to monitor the fluid's condition.						

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.