



Customer: PTRHTF10167	System Information	Sample Information			
Polartec Tennessee Manufacturing LL	System Volume: 2865 gal	Lab No: 02537221			
310 Industrial Dr. S. W	Bulk Operating Temp: 525F / 274C	Analyst: Jake Finn			
Cleveland, TN 37311 USA	Heating Source:	Sample Date: 01/25/23			
Attn: Scott McMahan	Blanket:	Received Date: 02/02/23			
Tel:	Fluid: PETRO CANADA CALFLO AF	Completed: 02/06/23			
E-Mail: scott.mcmahan@milliken.com	Make: HEATEC	Jake Finn			
		iake.finn@HESinclair.com			

Recommendation: Overall the fluid is in decent condition, no signs of fluid contamination or wear of internal components. Flash point has dropped and viscosity is low as well. If possible, a proper venting of the system may release some of the low boilers that are contributing to this low viscosity and flash point. If venting is not possible or does not resolve the issue, a partial sweetening of the system fluid may also be considered (replace 10-20% of the fluid to replenish additive reserves). If the fluid has truly been in service for 24 years, then during the next planned shutdown, you may also consider replacing the fluid with Fresh Calflo AF if venting does not resolve the lower flash point. If venting is done or system fluid is sweetened, feel free to request analysis to confirm any changes, otherwise please submit for retesting in 12 months to continue monitoring fluid condition.

Comments: COC Flash Point is abnormally low. Visc @ 40°C is abnormally low. Very light visual debris noted by lab.

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
01/25/23	02/02/23	24.0y		334 / 168	13.7	24.3	0.04	0.196	671 / 355	787 / 419	895 / 479	5.90
02/22/22	03/02/22	23.0y	Drain Valve	388 / 198	12.2	26.4	0.04	0.033	672 / 355	785 / 419	891 / 477	5.84
01/25/21	02/01/21	22.0y	Drain valve	410 / 210	9.6	28.9	0.06	0.065	683 / 361	788 / 420	893 / 479	4.03
12/14/15	12/17/15	18.0y	PUMP INLET	372 / 189	8.0	27.7	0.07	0.037	687 / 364	783 / 417	882 / 472	1.77





Judging by the green flags, the oil condition is not so bad. Flash point is still strong enough for 525F operation, oxidation is minimal because of the nitrogen blanket. 12/14/15 Overall the oil looks ok. However, if the oil life is truly 18 years as indicated, we would use the next shut down as an opportunity to replenish som eof the additive reserve in the fluid by sweetening the system, i.e. replace a certain percentage (10% or 20%) of used oil with fresh Calflo. COC Flash Point is marginally low.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.