



Customer: PTRHTF10039 System Information Sample Information **Piedmont Chemical Industries** System Volume: 750 gal Lab No: 02539374 331 BURTON AVE. Bulk Operating Temp: 536F / 280C Analyst: Manny Garcia HIGH POINT, NC 27261 USA Heating Source: Sample Date: 02/06/23 Attn: JUSTIN RUSSELL Blanket: Received Date: 02/14/23 Fluid: PETRO CANADA CALFLO AF Tel: (336)885-5131 Completed: 02/17/23 Make: FULTON E-Mail: JRUSSELL@PIEDMONTCHEMI Manny Garcia CAL.COM manuel.garcia@HFSinclair.com

Recommendation: Excellent Used Oil Analysis Results - Please re-submit sample in February 2024.

Comments: Suitable for Continued Use.

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
02/06/23	02/14/23	15.0y	PUMP	421 / 216	0.00	31.9	0.02	0.066	713 / 379	803 / 428	903 / 484	0.78
03/07/22	03/17/22	11.0y		432 / 222	7.6	30.6	0.01	0.012	704 / 373	798 / 425	896 / 480	1.19
05/23/18	06/05/18	6.0y		424 / 218	9.8	30.3	0.01	0.033	716 / 380	793 / 423	891 / 477	0.00
03/27/17	03/30/17	5.0y	MAIN CIRC PUMP	421 / 216	4.0	30.4	0.03	0.156	708 / 375	808 / 431	920 / 493	0.92
03/28/16	04/01/16	4.0y	AT MAIN CIRCU. PUMP	396 / 202	0.00	30.6	0.032	0.033	694 / 368	795 / 424	893 / 479	1.54





Historical Comments

03/07/22	Fluid Sample is Satisfactory and suitable for continued use. Please schedule the next sample for March 2023. Viscosity of the oil is perfect, contamination low and the distillation points in check. Very light debris noticed in the sample of fluid and changing system filters (if any) is recommended and potentially cleaning the fluid with an on-line oil filtration system (kidney loop)
05/23/18	Oil is suitable for continued use. Please re-submit the next sample during May 2019
03/27/17	Mitigation of the high 90% distillation point can be done by 'venting' the system. Please submit any new samples into the lab for verification of maintenance performed. Otherwise, submit annual sample to the lab as recommended.Wear Metals are low; Contaminant Levels are Low; Water contamination is satisfactory; Viscosity is acceptable; COC Flash Point is good; (GCD) 90% Distillation Point is abnormally high. Pentane insoluble are low; Very light white metal & debris noticed in sample visually;
03/28/16	Sample is in acceptable condition and suitable for continued use. Please re-submit sample during next scheduled interval. Wear metals low; contaminant levels low; additive levels good; water is low; Acid numbers are low; Flash Point is good; distillation curves are low; Pentane solids low; very light debris seen visually

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.