





LINE 2

Customer: PTRHTF10164

Malarkey Roofing 3400 S. Council Rd

OKLAHOMA CITY, OK 73179 US Attn: MALARKEY ROOFING

Tel: (405)261-6900

E-Mail: bdaverede@malarkeyroofing.com

System Information

System Volume: 3500 gal

Bulk Operating Temp: 565F / 296C

Heating Source:

Blanket:

Fluid: PETRO CANADA CALFLO HTF

Make: AMERICAN HEATING

Sample Information

Lab No: 02541174 Analyst: Garrett Bapp Sample Date: 01/03/23 Received Date: 02/23/23 Completed: 03/10/23


Garrett Bapp

Garrett.Bapp@HFSinclair.com

Recommendation: System is in overall good health. Viscosity is slightly lower than base line along with a lower than desirable flash point indicating thermal degradation is occurring. Recommend to vent system and sweeten system with 30% new oil. Resample in 1 year.

Comments: COC Flash Point is abnormally low. Visc @ 40°C is abnormally low.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.