



**A9**

Customer: PTRHTF30026	System Information	Sample Information
<b>MERIDIAN</b> 155 HIGH STREET EAST STRATHROY, ON N7G 1H4 CANADA Attn: DAVE GOODCHILD (MPD) Tel: (519)245-4040 E-Mail: DGOODCHILD@MERIDIAN-MAG.COM	System Volume: 40 gal Bulk Operating Temp: 400F / 204C Heating Source: Blanket: Fluid: PETRO CANADA PETRO-THERM Make: MOKON	Lab No: 02541175 Analyst: Behshad Sabah Sample Date: 02/20/23 Received Date: 02/23/23 Completed: 03/22/23 Behshad Sabah behshad.sabah@HFSinclair.com

Recommendation: The test results show that the oil is in a good shape and condition. no more action needed for this year. another sample should be sent to the lab in next year.

Comments:

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
02/20/23	02/23/23	3.0m		450 / 232	0.00	31.6	0.25	0.095	715 / 380	810 / 432	905 / 485	2.49
Baseline Data				433 / 223		34.2	0.03		720 / 382	817 / 436	900 / 482	1.00



