

ATLANTIC STATES

Customer: PTRHTF10041
 KUTTNER LLC.
 211 N FRANKLIN ST
 PORT WASHINGTON, WI 53074 USA
 Attn: DAVID ZINKY
 Tel: (262)284-4483
 E-Mail: d.zinky@kuttnerna.com




System Information
 System Volume: 7000 gal
 Bulk Operating Temp: 540F / 282C
 Heating Source:
 Blanket:
 Fluid: MOBIL MOBILTHERM 603
 Make: WUERZ



Sample Information
 Lab No: 02543072
 Analyst: Yvette Trzcinski
 Sample Date: 01/06/23
 Received Date: 03/03/23
 Completed: 03/30/23
 Yvette Trzcinski
 yvette.trzcinski@HFSinclair.com

Recommendation: The results appear to show thermal cracking of the fluid which is creating low boilers which could lead to cavitation of the pumps as well as the lowering of the GCD boiling point at 90%. Consider venting the system to remove the low boilers before they cause issues with pump cavitation, as well as, consider sweetening the system by adding at least 30% of new heat transfer fluid to the system

Comments: (GCD) % < 335°C is severely high. (GCD) 90% Distillation Point is severely low. (GCD) 10% Distillation Point is abnormally low.




| Sample Date | Received Date | Fluid Age | Sample Location | Flash Point (COC) | Water (KF) | Viscosity (40°C) | Acid Number | Solids | GCD 10% | GCD 50% | GCD 90% | GCD % < 335°C |
|----------------------|---------------|-----------|-----------------|-------------------|------------|------------------|-------------|--------|-----------|-----------|-----------|---------------|
| | mm/dd/yy | | | °F/°C | ppm | cSt | mg/KOH/g | %wt | °F/°C | °F/°C | °F/°C | % |
| 01/06/23 | 03/03/23 | 60.0m | | 356 / 180 | 31.2 | 18.9 | 0.25 | 0.165 | 604 / 318 | 679 / 359 | 765 / 407 | 21.59 |
| 06/24/18 | 08/22/18 | 0.0m | PUMP INLET | 397 / 203 | 80.7 | 22.4 | 0.02 | 0.058 | 675 / 357 | 764 / 407 | 845 / 452 | 2.72 |
| 08/21/16 | 09/19/16 | 18.0m | PUMP INLET | 417 / 214 | 130.5 | 19.7 | 0.11 | 0.092 | 710 / 376 | 791 / 421 | 877 / 469 | 0.37 |
| 04/14/15 | 06/05/15 | 2.0m | PUMP INLET | 428 / 220 | 199.7 | 28.1 | 0.15 | 0.061 | 709 / 376 | 791 / 422 | 870 / 465 | 0.45 |
| 12/22/10 | 01/10/11 | | PUMP INLET | 405 / 207 | 430 | 24.4 | 0.27 | 0.070 | 704 / 374 | 774 / 412 | 847 / 453 | 0.301 |
| Baseline Data | | | | 379 / 193 | | 20.2 | 0.03 | | 676 / 358 | | 858 / 459 | 2.6 |





| Sample Date | Iron | Chromium | Nickel | Aluminum | Copper | Lead | Tin | Cadmium | Silver | Vanadium | Silicon | Sodium | Potassium | Titanium | Molybdenum | Antimony | Manganese | Lithium | Boron | Magnesium | Calcium | Barium | Phosphorus | Zinc |
|---------------|------|----------|--------|----------|--------|------|-----|---------|--------|----------|---------|--------|-----------|----------|------------|----------|-----------|---------|-------|-----------|---------|--------|------------|------|
| 01/06/23 | 32 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/24/18 | 15 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 5 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 15 | 0 | 0 | 1 |
| 08/21/16 | 4 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 37 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 57 | 0 | 2 | 0 |
| 04/14/15 | 19 | 0 | 0 | 0 | 0 | 0 | 1 | 0 | 0 | 0 | 0 | 45 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 64 | 0 | 2 | 1 |
| 12/22/10 | 11 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 88 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 89 | 0 | 2 | 0 |
| Baseline Data | | | 0 | 0 | | | | | | 0 | | | 0 | 0 | | | | | 0 | | | | 0 | |

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



| Historical Comments | |
|---------------------|--|
| 06/24/18 | No reference sample. Fluid changed 01/28/2018 viscosity, acid number, flash point, insolubles and distillation at acceptable levels resample at normal intervals |
| 08/21/16 | No reference fluid available. Viscosity at 40C appears low compared to previous samples. High Sodium and calcium contamination. TAN is acceptable. COC Flash Point is severely high. Calcium ppm levels are severely high. Visc @ 40°C is severely low. Sodium ppm levels are abnormally high. |
| 04/14/15 | Baseline and typical values not available. Product unknown so cannot make a complete diagnosis. TAN, Flash Pt, Insolubles, H2O, Fe, GCD all appear good. Na and Ca contamination. Sodium ppm levels are severely high. Calcium ppm levels are severely high. |
| 12/22/10 | The oil has some moisture in it, not dramatic but enough to be heard and cause some issues in some systems depending on the design. The oil also contains minerals like sodium and calcium, maybe salt water. Please try to prevent water ingress. Re-sample in 6-9 months. |

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.