



IDEMITSU DAPHNE QUENCH

Customer:

CANADIAN CHEMICAL CLEANING 1099 HWY #6, R.R. #2 HAMILTON, ON L8N 2Z7 CA

Attn: Len MacDonald Tel: (905)689-2266

E-Mail: len.macdonald@reladyne.com

System Information

System Volume: 0 gal

Bulk Operating Temp: Not Specified

Heating Source:

Blanket:

Fluid: IDEMITSU DAPHNE THERMIC OIL 32-S

Make:

Sample Information

Lab No: 02545619

Analyst: Bill Quesnel CLS,OMA II,MLA-

III,LLA-I

Sample Date: 03/02/23 Received Date: 03/15/23 Completed: 04/14/23

Bill Quesnel CLS,OMA II,MLA-III,LLA-I

Recommendation: We recommend an early resample to monitor this condition. Diagnostician's Note: The thermal fluid boiling points and viscosity are in good efficiency range, however, acid number result is extremely high, and likely the thermal fluid will be corrosive to the system. Recommend resample in 3 months to monitor.

Comments: There is a moderate concentration of water present in the fluid. Acid Number (AN) is severely high. (GCD) 90% Distillation Point is severely low. The high AN level of the fluid indicates the presence of oxi-polymerized products. The AN level is much higher than the recommended limit.



