



[IKO - IG Machines & Fiber Brampton] FK371-R

Customer:	System Information	Sample Information
Environmental 360 Solutions Ltd. 640 Victoria Street Cobourg, ON K9A 5H5 Canada Attn: Tatiana Sorkina Tel: E-Mail: tsorkina@e360s.ca	System Volume: Bulk Operating Temp: Not Specified Heating Source: Blanket: Fluid: PETRO CANADA PETRO-THERM Make:	Lab No: 02547433 Analyst: Bill Quesnel CLS,OMA II,MLA-III,LLA-I Sample Date: 03/10/23 Received Date: 03/24/23 Completed: 03/29/23 Bill Quesnel CLS,OMA II,MLA-III,LLA-I

Recommendation: The fluid is suitable for further service. No corrective action is recommended at this time. Resample at the next service interval to monitor.

Comments: (GCD) 90% Distillation Point is marginally high.

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
03/10/23	03/24/23	0.0h			10.7	35.6	0.20	0.058	697 / 370	788 / 420	922 / 495	3.23
Baseline Data				433 / 223		34.2	0.03		720 / 382	817 / 436	900 / 482	1.00



