

[TOURMALINE OIL CORP / LSD 4-17-51-18W5] TOURMALINE EDSON PLANT UH-5000

Customer: PTRHTF20039
 BRENNTAG CANADA INC
 3124-54TH AVENUE SE
 CALGARY, AB T2C 0A8 Canada
 Attn: Matthew Kryska
 Tel:
 E-Mail: mkryska@brenntag.ca




System Information
 System Volume: 19000 ltr
 Bulk Operating Temp: 437F / 225C
 Heating Source:
 Blanket:
 Fluid: PETRO CANADA PETRO-THERM
 Make:


Sample Information
 Lab No: 02549152
 Analyst: Lyle Dach
 Sample Date: 03/08/23
 Received Date: 03/31/23
 Completed: 04/10/23
 Lyle Dach
 lyle.dach@HFSinclair.com

Recommendation: Sample results indicate that the fluid is in suitable condition for continued service. Resample in 12 months.

Comments:




Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
03/08/23	03/31/23	0.0y	sight glass	424 / 218	13.0	34.9	0.26	0.096	716 / 380	813 / 434	912 / 489	2.32
03/15/22	04/11/22	2.0y	sight glass	439 / 226	171.6	28.7	0.11	0.055	718 / 381	813 / 434	915 / 490	2.10
03/15/21	03/30/21	5.0y	Pump suction	457 / 236	7.2	34.9	0.08	0.051	720 / 382	815 / 435	924 / 496	1.10
01/11/21	01/22/21	6.0y	SITE GLASS	432 / 222	11.1	34.0	0.10	0.080	726 / 386	815 / 435	913 / 490	0.52
01/15/20	02/03/20	5.0y		460 / 238	7.2	35.2	0.061	0.078	723 / 384	806 / 430	903 / 484	0.00
Baseline Data				433 / 223		34.2	0.03		720 / 382	817 / 436	900 / 482	1.00





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
03/08/23	2	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
03/15/22	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
03/15/21	1	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0
01/11/21	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
01/15/20	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Baseline Data			0	0						0			0	0					0				0	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments

03/15/22	Sample results indicate the fluid is in suitable condition for continued service. Viscosity has been reduced yet flash point, distillation curve and low boiling vapor content are in good condition. Please re-sample in 12 months.
03/15/21	Fluid remains in excellent condition. No change since previous sample in January 2021. (GCD) 90% Distillation Point is marginally high.
01/11/21	This fluid appears to be in good condition. Maintain good system maintenance practices and resample in 6 months.
01/15/20	The fluid is in good condition and suitable for further use. Please re-sample in 12 months.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.