



## [Seremban Malaysia] TFS

## Customer: PTRHTF60036

ALLNEX MALAYSIA SDN BHD PT 12701, TUANKU JAAFAR IND. PARK

NEGERI SEMBILON

SEREMBAN, 71450 Malaysia Attn: Norhisham Bin Abal Rahman

Tel: 6(012)607-6575

E-Mail:

## **System Information**

System Volume: 6000 gal

Bulk Operating Temp: 545F / 285C

Heating Source:

Blanket:

Fluid: PETRO CANADA PURITY FG HEAT TRANSFER FLUID

Make: Welshaupt and Dunphy

## Sample Information

Lab No: 02550514

Analyst: Bill Quesnel CLS, OMA II, MLA-

III,LLA-I


Sample Date: 03/24/23 Received Date: 04/10/23 Completed: 04/17/23

Bill Quesnel CLS, OMA II, MLA-III, LLA-I

Recommendation: We recommend that you vent the expansion tank to remove low boilers which assists in restoring the flash point of the fluid. We advise an early resample to confirm this situation. NOTE: This appears to be a 50/50 mixture of two thermal fluid products.

Comments: (GCD) % < 335°C is severely high. (GCD) 10% Distillation Point is severely low. COC Flash Point is severely low. Visc @ 40°C is abnormally low.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.