

P1 HOT OIL BOILER

Customer: PTRHTF10083
 KAO SPECIALTIES AMERICAS LLC
 243 WOODBINE ST/PO BOX 2316
 HIGH POINT, NC 27260 US
 Attn: ROBERT WILLIAMS
 Tel: (336)878-4225
 E-Mail: rwilliams@ksallc.com




System Information
 System Volume: 7000 gal
 Bulk Operating Temp: 550F / 288C
 Heating Source:
 Blanket:
 Fluid: PETRO CANADA CALFLO AF
 Make: FIRST THERMAL



Sample Information
 Lab No: 02556040
 Analyst: Manny Garcia
 Sample Date: 05/01/23
 Received Date: 05/08/23
 Completed: 05/12/23
 Manny Garcia
 manuel.garcia@HFSinclair.com

Recommendation: 'Venting' the HTF system may assist in mitigating these extremely unsatisfactory values & some dangerously off. For the 2nd time in 8 months these values have not improved. Please vent the system, take another sample and submit for fluid quality verification.

Comments: (GCD) 10% Distillation Point is severely low. COC Flash Point is severely low @ 130oC (266oF). Visc @ 40°C is severely low & out of range from an ISO 32 as formulated to an ISO 22 range, but low on that scale of 18.9 CsT @40oC. (GCD) % < 335°C is marginally high.




Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
05/01/23	05/08/23	0.0y		266 / 130	46.6	18.9	0.11	0.296	595 / 313	778 / 415	889 / 476	11.99
09/29/22	10/11/22	0.0y	HOT OIL PUMP	259 / 126	11.9	21.1	0.06	0.104	643 / 340	784 / 418	891 / 477	8.93
11/19/21	11/26/21	0.0y		460 / 238	4.8	32.3	0.04	0.049	705 / 374	799 / 426	900 / 482	0.71
03/15/21	03/22/21	0.0y		302 / 150	17.3	17.7	0.27	0.224	568 / 298	772 / 411	906 / 485	15.49
11/02/20	11/06/20	0.0y	Main hot oil pumps	316 / 158	18.0	18.5	0.16	0.344	588 / 309	770 / 410	886 / 475	13.87
Baseline Data				435 / 224		32.7	0.03		693 / 367	790 / 421	887 / 475	2.5





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
05/01/23	53	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	71	0
09/29/22	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	20	0
11/19/21	0	0	0	0	0	0	0	0	0	0	4	0	0	0	0	0	0	0	0	0	0	0	285	4
03/15/21	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	11	0
11/02/20	11	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	6	0	24	5
Baseline Data			0	0						0			0	0					0				270	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments	
09/29/22	Lab has received 2 fluid samples from this same system. Phosphorous levels should be in the 280 ppm range and this fluid is down in the 20 ppm range. The viscosity of the fluid is down 1 full grade, which is not satisfactory and very uncommon for a relatively new fluid. The COC flash point is VERY dangerously low at 126oC whereby the fluid by design is supposed to be in the 217oC range. This flash point needs to be addressed and mitigated immediately! Can we confirm this is a fluid sample from the system in the month of September, please? These results appear to look like the 'old' fluid before it was changed out in 2021. The previous results on Nov, 2021 were perfect.
11/19/21	Please re-submit sample in November 2022 to confirm status. Sample of Calflo AF looks perfect across all parameters for this system.
03/15/21	The past samples for this Fluid charge have consistently shown that the useful life of the fluid has been exceeded & should be considered for a fluid change-out. (GCD) 10% Distillation Point is severely low. COC Flash Point is severely low. Visc @ 40°C is severely low. (GCD) % < 335°C is abnormally high. (GCD) 90% Distillation Point is marginally high.
11/02/20	In the past we have recommended this system be vented to 'potentially correct/mitigate the issues mentioned with the fluid. Our records don't indicate the age of the fluid, but the product may have worked thru its useful life. Our recommendation is to drain, flush and re-charge the heat transfer system for improved efficiencies, safety and production levels. (GCD) 10% Distillation Point is severely low & has been trending this way for the last 4 years. COC Flash Point is severely low & this could cause a fire in your facilities if not corrected - has been dangerously low for the last 4 years. Visc @ 40°C is severely low & has been for the last 4 years. (GCD) % < 335°C is abnormally high.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.